

TENBROOK ROAD SIDEWALK – ADDENDUM #1
City of Arnold, MO
Federal Project SRTS-INF-H32F(105)
February 17, 2017

This addendum is hereby made part of the contract documents of the above referenced project. This addendum supplements and/or amends the originally issued documents and all related addenda.

The City of Arnold is making the following modifications and/or clarifications to the contract documents for this project:

1. A question was posed at the pre-bid meeting asking if there would be an option for the sidewalk to be poured monolithic with the adjacent curb. The City's response is the sidewalk must be poured separate as indicated in the drawings.

2. Some areas of the specifications indicate the bid guaranty shall meet the requirements of Section 102 of the Missouri Standard Specifications for Highway Construction. Section 102 refers to a bid guaranty amount of no less than 5% of the amount of the bid. However, the amount of the bid guarantee for this project shall be no less than 10% of the amount of the bid as stated on the Invitation for Bids.

Attachments:

- Pre-Bid Meeting sign-in sheet.

ACKNOWLEDGEMENT OF ADDENDUM #1

The bidder will acknowledge receipt of this Addendum and acceptance of its conditions by signing this Addendum and including it with the bid.

SIGNATURE: _____

TITLE: _____

COMPANY: _____

DATE: _____

