



ISSUE DATE: March 1, 2017

ADDENDUM NUMBER 1

Project Number: **TAP 3301-494**

Project Title: **Brush Creek and Blue River Confluence Trail**

Bidders are hereby notified that the Bidding and Contract Documents for the above project, for which Bids are to be received on **March 8, 2017**, are amended as follows:

Information to Bidders The following is provided to Bidders for information only:

1.04 ENGINEER: HDR

2.01 This Addendum forms a part of the Contract Documents and modifies the Bidding Documents, with amendments and additions noted below.

Item #1-Pre-bid meeting. Sign in sheet from the meeting is attached.

Item #2-Pre-bid meeting questions and answers. Below are the questions and answers of the meeting.

1. Question: Do you have cut/fill calculations for the cross sections in the plans for the trail?
Answer: *We will provide to the successful bidders.*
2. Question: There is quite a bit of trash, debris and tires along the footprint of the trail. Will there be a bid item for disposal of these items? Answer: *Contractor will add to mobilization number.*
3. Question: Clearing and grubbing extends 30ft each side of the trail, however the seeding quantity is for just 2 acres? Answer: *Contractor will be paid for actual area seeded.*
4. Question: What are the permits and fees indicated on line 10 of plan sheet 12 for this project? Answer: *There is UP Railroad Flagmen Fee. UPRR estimated at \$17,000.*
5. Question: Can Blue Banks Park on the south side of the pedestrian bridge be utilized as a staging area? Answer: *Yes and the area around the specimen tree will need to be fenced.*
6. Question: The bid documents have 2 DBE percentages listed on the submittal forms one has 9% as the goal the second has 5%? Answer: *The DBE participation is 5%*
7. Question: Has the Union Pacific RR provided a cost for working inside their ROW, ie: Right of entry. RR insurance, flagmen? Answer: *Estimated at \$17,000*
8. Question: Property Insurance is a requirement of this project? Answer: *Standard City / MoDOT requirements as listed in the specifications.*

9. Question: Clearing is not restricted to any time period due to the acreage to be disturbed?
Answer: *The City removed the trees already with the restricted removal period. Note the contractor to remove all remaining trees per plans and specifications.*

10. Question: Will the UPRR be present at the pre-bid meeting? Answer: *No*

11. Question: I would like to know if they (the RR) will require shoring or piles for the work within their ROW or any other specific requirements and who is the contact for the railroad and who is the railroad contact. Answer: *Plans have been reviewed by the UP and approved.*

*Mike Benjamin
Manager of Special Projects Industry and Public
Union Pacific Railroad Company
600 Broadway
Kansas City MO. 64105
Phone (816) 399-1703*

12. Question: Who will be performing material testing inspections? Answer: *Will be done by KCMO Material Testing*

13. Question: Who will perform the bridge inspection? Answer: *Inspections will be done by a consultant*

14. Question: Can the rock riprap from the temporary crossing be used along the bank after the temporary crossing is removed? Answer: *Yes*

15. Question: Can E. 45th St/ E. Cole Mine Rd be used to access the north side of the project. ? Answer: *No, Union Pacific Railroad owns land immediately east of the railroad track and the current agreement for this project did not include this Railroad Property area.*

16. Question: Can the pile cap be modified to remove the cantilever where the cap is bigger than the rest of the structure? Answer: *No. Bid as drawn and specified.*

NOTE: Bidders must acknowledge receipt of this Addendum by listing the number and date, where provided, on the Bid Form - Document 00410.

CERTIFICATE BY BIDDER/PROPOSER

I acknowledge receipt of this Addendum No. 1 for Project No **TAP 3301-494: Brush Creek Confluence Trail Improvements** and that the bid/proposal is in accordance with the information, instructions, and stipulations set forth herein.

By _____

Company _____

NOTE: This signed addendum notice must accompany your bid.

Meeting Sign-In

Project: Brush Creek Confluence Trail

Date: 2-28-17

Facilitator: Allen

Time: 4:30

Place/Room: Park Board Room

Print Name	Organization	Title	Phone	Email
1. Richard Allen	KC PARKS	PROJECT MANAGER	513-7713	richard.allen@kcmo.org
2. David Hoggard	J.M. Foley Const. Co	Estimator	816-743-3010	davehoggard@jmfcoy.com
3. Dirk Hudson	ESI Contracting	Project Engineer	816-352-5526	dhudson@esi-cc.com
4. Mark Holmes	PYRAMID CONTRACTORS	Project Manager	913-764-6225	mhp@pyramid@sbcglobal.net
5. STEVE KASPAR	LG BARCUS	ESTIMATOR	913-621-1100	STEVE.KASPAR@BARCUS.COM
6. Brian Zeiger	HDR	Engineer	816-360-2730	brian.zeiger@hdrinc.com
7. Steve Toth	Mega Industries Corporation	ESTIMATOR	816-472-8722	bids@mega-bids.com
8. Dan Murray	Four Star Const	Estimator	816-482-1838	dmurray@koegnaul.com
9. JEROD KELLEY	CUNTER CONSTRUCTION	ESTIMATOR	(620) 228-3439	bids@cunten.kc.com
10. Ruben Lara	KC HD	Contract Compl.	816 513-2648	Ruben.lara@kmo.org
11.				
12.				