



TAYLOR ENGINEERING, L.L.C.

109 E. COLUMBIA - P.O. BOX 674
FARMINGTON, MO 63640

(573) 756-9226 - FAX (573) 756-7310

City of Park Hills, Missouri
Donnelly-LaMear Trailhead
and Hiking/Biking Trail

ADDENDUM #2

The above referenced project is to be amended as follows:

1. See attached detail - If bidding asphalt Hiking/Biking trail, width shall be 8.50' wide. If bidding concrete Hiking/Biking trail, width shall remain 8' wide.
2. Remove and replace the bid tab with the revised bid tab provided.
3. Mulch shall be an allowable substitution in lieu of silt fence.
4. MoDOT Type 2 ditch checks shall be placed at storm pipe inlets and outlets per MoDOT standard detail.
5. The asphalt shall be placed in a single 3" lift.
6. DNR will allow tree burning.
7. Site grading note 9 shall be revised as follows:
ALL DISTURBED AREAS SHALL LEAVE A SMOOTH SURFACE SUITABLE TO RECEIVE SEED. SURFACE ROCK 1-1/2" OR GREATER IN ANY DIMENSION SHALL BE REMOVED FROM ALL FINISH GRADED AREAS. CONTRACTOR SHALL BE RESPONSIBLE FOR ALL SEEDING AND MULCHING WORK.
8. See attached Pre-Bid Meeting sign in sheet.


End Addendum #2



Issued April 13, 2018
Taylor Engineering, LLC
P.O. Box 674
Farmington, MO 63640
(573) 756 - 9226

6" CRUSHED STONE BASE
1" MINUS
(COMPACTED TO 98 %
OF STANDARD PROCTOR)

3" ASPHALT



2.00 % MAX SLOPE
1.00% MIN SLOPE

8.50' WIDE ASPHALT TRAIL

DETAIL

Not To Scale

<p style="text-align: center;">BID TAB DONELLY-LAMEAR TRAILHEAD AND HIKING/BIKING TRAIL CITY OF PARK HILLS MARCH 30, 2018 Revised April 13, 2018</p>					
Item	Description	Quantity		TE Estimate	
				Unit Price	Total Price
1	Mobilization	1	LUMP		
2A	8.50' ASPHALT HIKING/BIKING TRAIL INCLUDES 3" ASPHALT, 6" BASE AND PRIME COAT	2,093	SY		
2B	8' CONCRETE HIKING/BIKING TRAIL INCLUDES 4" CONCRETE, STEEL REINFORCEMENT AND 3" CRUSHED STONE	1,970	SY		
3	ASPHALT PARKING LOT INCLUDES 3" ASPHALT, 8" TYPE 5 BASE AND PRIME COAT	1,391	SY		
4	8" TYPE 5 CRUSHED STONE PARKING LOT	4,592	SY		
5	PARKING LOT STRIPING INCLUDING HANDICAP SYMBOLS AND STRIPING	426	LF		
6	HANDICAP SIGNAGE	3	EA		
7	VAN ACCESSIBLE STRIPING	2	EA		
8	6" STEEL BOLLARDS, CONCRETE FILLED AND PAINTED YELLOW	2	EA		
9	24" HDPE PIPE INSTALLED AND COMPLETE	369	LF		
10	24" HDPE FES	6	EA		
11	ROCK LINING FOR CULVERT OUTLET PER STANDARD PLAN SHEET 609.70C	18	CY		
12	4' X 4' AREA INLET	4	EA		
13	10" SCH 80 PVC	32	LF		
14	6" SCH 80 PVC	32	LF		
15	2" ELECTRICAL CONDUIT	32	LF		
16	OFF ROAD VEHICLE BARRIER FENCE	60	LF		
17	EXCAVATION (CUT)	14,977	CY		
18	EXCAVATION (FILL)	23,910	CY		
19	ROCK EXCAVATION	200	CY		
20	CLEARING AND GRUBBING	4.10	AC		
21	SEEDING AND MULCHING	3.00	AC		
22	SILT FENCE	2,200	LF		
23	Type 2 Ditch Check at Storm Pipe Inlet and Outlet per MoDOT Standard Detail	10	EA		
24	STRAW BAIL SEDIMENT TRAP	5	EA		
TOTAL					
TOTAL BID WRITTEN:					

*CONTRACTOR SHALL ONLY BID EITHER ITEM 2A OR 2B.