



ADDENDUM NUMBER ONE

DATE: April 14, 2017

OWNER: Pike County, Missouri
119 E. Park Drive
Bowling Green, Missouri 63334

SUBJECT: Addendum Number One to
Bridge Replacement over Branch of East Sulphur Creek
Federal Project No. BRO-B082(30)
Cochran Project No. SC15-527

This Addendum forms a part of the Bidding and Contract Documents and modifies the original Bidding Documents. **FAILURE TO ACKNOWLEDGE RECEIPT OF ADDENDUM MAY SUBJECT BIDDER TO DISQUALIFICATION.**

ITEM:

1. **CLARIFICATION:** The quantity of epoxy coated reinforcing steel to be placed in the bridge deck as shown in the "Estimated Quantities for Slab on Concrete NU-Girder" table on Sheet B-3 and the Epoxy Steel total on Sheet B-12 is incorrect. Instead of the 1,407 pounds shown in the Plans, the correct quantity of epoxy coated reinforcing steel should be 9,594 pounds. This quantity of epoxy coated reinforcing steel is included in the price bid for Slab on Concrete NU 1100 Girder, per square yard.

END ADDENDUM NO. 1