

Missouri Department of Transportation
David B. Nichols, Director

573.751.2551
Fax: 573.751.6555
1.888.ASK MODOT (275.6636)

ADDENDUM 002
Jackson and Kewanee Pole Barns
Request for Bid 9-141107BR

Bidders should acknowledge receipt of Addendum 002 (TWO) by **signing** and **including** it with the original bid. The due date for receipt of bids is **unchanged** by this Addendum. The following question and answer/clarification are believed to be of general interest to all potential Bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Beth Rodeman General Services Specialist
Contractor/Bidder Signature	Department of Transportation 
(Signature of person authorized to sign)	(Authorizing Signature)
Date Signed:	Date Signed: October 31, 2014

Vendor Question:

Will these (unit heaters) run off of natural gas or propane, sheet # 5 calls for propane, but sheet # 12 states Natural gas. If they (the unit heaters) are propane, how far to the tanks?

CLARIFICATION:

There will be no propane service requirements for the Jackson and Kewanee pole barn locations. Natural gas piping for utility services is required on both projects as clarified in Addendum 001.



Our mission is to provide a world-class transportation experience that delights our customers and promotes a prosperous Missouri.

www.modot.org