

Missouri
Department
of Transportation



Roger Schwartz, District Engineer

Central District
1511 Missouri Boulevard
P. O. Box 718
Jefferson City, MO 65102
(573) 751-3322
fax (573) 522-1059
Toll free 1-888 ASK MoDOT
www.modot.org

September 10, 2010

RE: Addendum 01 to Bid D5-11-005B, Fuel Tanks

Dear Bidders:

Please note that this addendum letter is to inform all potential bidders of the following changes to D5-11-005B.

Change (A)

The bid posting currently reads:

Item 1 (1000 gal)
MOKANE MAINTENANCE SHED (Callaway County)
10165 STATE RD. C
MOKANE, MO 65059

Shall read:

Item 1 (1500 gal)
MOKANE MAINTENANCE SHED (Callaway County)
10165 STATE RD. C
MOKANE, MO 65059

Pricing page is to be adjusted as well.

Change (B)

Please note that all fuel tanks shall a total of eight openings: Two six (6") vents as listed in the specification; three two (2") inch vents and three four (4") inch vents, four of which shall be capped.

If you have any questions, please call.

Thank you!

Corey Duemmel, D5 General Services
(573) 526-6956



FUEL TANKS PRICING PAGE
(Bid D5-11-005B)

Addendum 01

Item 1: 1,500 Gallon, Double Wall Tank for Diesel Fuel
(UL 142 Certified, SWRi label for Fire Resistant)

_____	_____	_____	_____
Brand/Model	Dimensions	Warranty	Delivery ARO
\$ _____			

Item 2: 1,500 Gallon, Double Wall Tank for Diesel Fuel
(UL 142 Certified, SWRi label for Fire Resistant)

_____	_____	_____	_____
Brand/Model	Dimensions	Warranty	Delivery ARO
\$ _____			

Item 3: 2,000 Gallon, Double Wall Tank for Diesel Fuel
(UL 142 Certified, SWRi label for Fire Resistant)

_____	_____	_____	_____
Brand/Model	Dimensions	Warranty	Delivery ARO
\$ _____			

Item 4: 2,500 Gallon, Double Wall Tank for Diesel Fuel
(UL 142 Certified, SWRi label for Fire Resistant)

_____	_____	_____	_____
Brand/Model	Dimensions	Warranty	Delivery ARO
\$ _____			

TOTAL LOWEST PRICE MEETING SPECIFICATION \$ _____