



**GENERAL NOTES:**  
Expansion device shall be fabricated in one section, except for stage construction and when the length is over 50 feet. A complete joint penetration groove weld shall be required. Welds shall be ground flush to provide a smooth surface. The expansion device shall be fabricated and installed to the crown and grade of the roadway.

Plan dimensions are based on installation at 60°F.  
The expansion gap and other dimensions shall be  
increased or decreased  for each 10° fall or rise  
in temperature at installation.

Material for the expansion device shall be ASTM A709 Grade 36 structural steel. Anchors for the expansion device shall be in accordance with Sec 1037.

Structural steel for the expansion device and curb plate shall be coated with a minimum of two coats of inorganic zinc primer (a minimum) or galvanized in accordance with ASTM A153. Anchors need not be protected from over spray.

Payment for furnishing, coating or galvanizing, and installing the structural steel for the expansion device will be considered completely covered by the contract unit price for Expansion Device (Flat Plate) per linear foot.

Concrete shall be forced under and around flat plate, anchors and angles. Proper consolidation shall be achieved by localized internal vibration. Finishing of the concrete shall be achieved by hand finishing within one foot of the expansion device. The vertical and horizontal concrete vent holes shall be offset from each other. Do not alternate holes at the 12" spacing.

Longitudinal reinforcing steel shall be placed so that ends shall not be more than  $\pm 1"$  from vertical plate and the vertical leg of the angle at the expansion device.

Complete joint penetration welds utilized in the fabrication of the expansion device shall be nondestructively tested by an approved method.

"THIS MEDIA SHOULD  
NOT BE CONSIDERED  
A CERTIFIED  
DOCUMENT."

DATE PREPARED 11/13/2012	
ROUTE *	STATE MO
DISTRICT 00	SHEET NO *

DR	*
COUNTY	*
JOB NO.	*

CONTRACT ID.
PROJECT NO.
BRIDGE NO.

[illegible][illegible]

DES

[illegible]

RTATION  
CAPITOL  
MO 65102

TRANSP  
ON  
105 WES  
PERSON CITY,



OT

MISS 

1

1

1

1

0:50 PM 11/13/20

[illegible]

1-888-ASK-MODOT (1-888-275-6636)

---