



STEEL WIRE BAR SUPPORTS MGS-92-14A

**1.0 DESCRIPTION.** These specifications cover the purchase of steel wire bar supports.

**2.0 MATERIALS.** The bar supports shall comply with the latest edition of the Manual of Standard Practice published by the Concrete Reinforcing Steel Institute.

**2.1** Bar supports shall be furnished as one of the following types. Unless otherwise specified in the bid request, either Type HC or CHC will be permitted.

Type HC, Class 3 - Individual high chair

Type CHC, Class 3 - Continuous high chair

**3.0 ORDERING INFORMATION.**

**3.1** The quantity and type is to be specified in the bid request.

**3.2** The height of the support is to be specified in the bid request in 1/4" increments from 2" to 15" maximum.

**4.0 CERTIFICATION.** The supplier of bar chair supports shall furnish to the engineer at destination a manufacturer's certification in triplicate stating that the material furnished complies with the requirements of the Manual of Standard Practice published by the Concrete Reinforcing Institute for the type specified.

**5.0 ACCEPTANCE.** Inspection of the material may be made at the point of manufacture, immediate storage point, or destination at the discretion of the department.