



---

## MEMORANDUM

---

TO: All Plan Holders

FROM: Crawford, Murphy & Tilly, Inc.

PROJECT: Ackert Walkway Improvements

DATE: June 7, 2019

SUBJECT: Addendum No. 1

PROJECT NUMBER: TAP-5402 (617)

---

This addendum forms a part of the Contract Documents for the Ackert Walkway Improvements Project. Contractors are required to acknowledge the receipt of addenda by signing and including all addenda with each bid form. FAILURE TO ACKNOWLEDGE RECEIPT OF ADDENDUM MAY SUBJECT BIDDER TO DISQUALIFICATION.

Notice to Bidders:

1. **Revised Construction Sheets.**

**Revised Sheet #3, Summary of Quantities Sheet 5 of 6:**

- Clarified that the intention was to use just the wires in the rigid conduit system and not cable-conduit into the rigid conduit system. The pay item names will remain the same on the bid form and in the plans, but only the wiring will be required (no cable-conduit). The note on the sheet reads:

“1" CABLE-CONDUIT IS LISTED AS THE PAY ITEMS FOR BOTH 2 COND. & 1 B.N. #6 AWG & #8 AWG. THE INTENTION WAS TO JUST USE THE WIRES AND NOT THE CONDUIT, SINCE THE WIRES WILL BE LOCATED IN A RIGID CONDUIT SYSTEM.

THE PAY ITEMS WILL REMAIN THE SAME AS CABLE-CONDUIT, BUT ONLY THE 3 WIRES FOR #6 AWG & #8 AWG WILL BE REQUIRED IN THE RIGID CONDUIT SYSTEM (NO CABLE-CONDUIT).”

**Revised Sheet #15, Lighting Sheet 1 of 4:**

- A detail was added for flexible plastic tubing between post and conduit at the direct burial base.
- A new detail was added to replace the previous detail regarding the pole. The correct catalog number is now SMA 12 L4E 09 P07 DBB BK (the previous catalog number SMA 12 S4J 09 P07 DBB BK was incorrect).

2. **Revised Job Special Provision.**

**Revised Sheet #54 of the Bid Book, JSP BB. Decorative Pole and Luminaire Fixtures:**

- JSP BB, Section 3.0 Materials: Catalog # SMA 12 L4E 09 P07 DBB BK was added as the correct one to replace SMA 12 S4J 09 P07 DBB BK.

Name and Title of Signer (Print or type)
Contractor / Bidder Signature
_____ (Signature of person authorized to sign)
Date Signed:

End of Addendum No. 1