



CITY OF ST PETERS
636.477.6600
bids@stpetersmo.net

August 8, 2018

RE: Addendum 2 - Bid 18-139 – Mid Rivers Mall Drive Corridor Improvements, Federal Project No. TAP 7305(616)

To all Contract Bidders of Record,

This Addendum, consisting of three (3) pages, is issued to answer questions received, modify, explain, or correct the original contract documents as noted below, and is hereby made a part of the contract documents.

1. On the Pay Item Partial Removal of Existing Bridge Decks what is the largest allowable hand/mechanical equipment that will be allowed?
 - Concrete shall be removed in accordance with Sec. 704. The existing bridge deck is rated a 6.
2. On the Pay Item Partial Removal of Substructure concrete what is the largest allowable hand/mechanical equipment that will be allowed?
 - Concrete shall be removed in accordance with Sec. 704.
3. For the Pay Item Safety Barrier Curb Railing, is there an alternate option of attaching to the top of the barrier wall? If the current post connection as shown on sheet 29 is required then the safety barrier curb will have to be hand formed and not slipformed.
 - Add the following note under the Post Connection Detail on Sheet 29 of 39. "In lieu of the cast-in-place anchor device shown, the Contractor has the option of drilling and setting ½" diameter resin anchor rods in accordance with Sec. 1039. Embedment shall be according to the manufacturer's specifications."
4. Will galvanized H pile be required on this project?
 - No
5. On the above mentioned project Items 120 Repair Bridge Deck, 121 Seal Wing Joint, and item 122 Epoxy Polymer Overlay are not listed in the plans on the Summary of Quantities Sheets nor in the bridge sections of the plans. Can revised sheets be issued to show this work and locations?
 - Please see the attached drawing on page three (3) of this addenda
 - Item 122 – Epoxy Polymer Overlay shall include the entire deck surface, including the newly constructed deck, as well as the bottom 1/3 of the concrete barrier on the traffic side.

Special Instructions Update:

- A. Important: Label the lower left corner of your sealed submittal package with the bid number and name
- B. Submit one original and one copy of your bid proposal
- C. Include Sections:
 - Sections Revised C, D, O, S (with E-Verify MOU), V, & W

Thank you,
City of St. Peters
bids@stpetersmo.net

Section – O - Addendum

ADDENDUM ACKNOWLEDGEMENT: The undersigned states that the all addenda's have been received, acknowledged, and incorporated into their bid prior to submittal. Complete and return with this proposal.

Addendum #1 July 31, 2018
Addendum #2 August 8, 2018

Addendum Received

By: _____

Signed: _____

(Signature of Authorized Representative)

Name _____

(Printed Name of Authorized Representative)

Title _____

Date _____