

CITY OF MEXICO, MISSOURI

NOTICE TO BIDDERS

ADDENDUM NO. 1

LIBERTY STREET IMPROVEMENTS STP-4400(309)


ISSUE DATE: August 1, 2017

Bidders shall note this change to the above reference project. This addendum shall be acknowledged in the bid form found on page 12 of the Specifications.

The following revisions and/or additions to the Plans and Specifications shall be referred to as part of the Specifications.

1. Plan Sheet 9 (Details) – Delete second note for Item No. 5 reading 'Sidewalk and curb to be poured integral to ensure compliance to ADA Guidelines'. The sidewalk and curb shall be poured separately and an expansion device shall be utilized between the two.

NO OTHER CHANGES



Issued by: Drew R. Williford
Registered Professional Civil
Engineer PE – 2016001320
Issued Date: 8/1/17