

**RECONSTRUCT EXISTING ASPHALT APRON  
FOR THE MACON-FOWER MEMORIAL AIRPORT  
CONTRACT NO. 16-31A-1  
ADDENDUM NO. 3**

April 27, 2017

Addendum No. 3 consists of the following clarifications, changes, additions, etc.

Clarifications:

1. Only those concrete slabs shown on Drawing C301 as being reinforced with wire mesh as designated by the R are to be reinforced. Detail 1, C501 shows wire mesh, however the mesh is only to be used in panels shown on C301 with the R designation.

Changes:

1. The depth of wire mesh reinforcement provided in Detail 1, C501 shall now be 3".
2. The depth of wire mesh reinforcement provided in Detail 6, C502 shall now be 3".

Acknowledge receipt and acceptance of this addendum in the appropriate space below.

Tom Dowse, PE  
Project Engineer  
Burns & McDonnell

\_\_\_\_\_  
Name of Firm

\_\_\_\_\_  
Signature of Authorized Person of Above Firm

\_\_\_\_\_  
Title

\_\_\_\_\_  
Date