

ADDENDUM No. 2
JEFFERSON CITY WAYFINDING SIGNAGE
TAP 9901(501)

CITY OF JEFFERSON – PUBLIC WORKS
April 22, 2016

Notice is hereby given to bidders that in reference to the subject project, the following modifications shall be noted. All other aspects of the Contract Documents remain in full force and effect.

The bidder will acknowledge receipt of this Addendum and his acceptance of its conditions by signing this Addendum and including it with his bid.

BIDDER:

BY:

TITLE:

Addendum Items

- 1) Plan Sheet Changes
- 2) Job Special Provisions Changes
- 3) Federal Wage Rate Revision

ADDENDUM No. 2
JEFFERSON CITY WAYFINDING SIGNAGE
TAP 9901(501)

1) PLAN SHEET CHANGES

1. Sheet G-100 – General Notes
 - a. Paragraph 5
 - i. The following note is added.
 - ii. All exposed fasteners should have a rounded head to reduce conspicuity.
2. Sheet G-103 (Sign Type C), Sheet G-105 (Sign Type D), G-110 (Sign Type E), and G-111 (Sign Type F)
 - a. The referenced section for breakaway assemblies for ground mounted signing is 903.03BE and 903.03AZ. Refer to the currently effective standard plan (as of the date of this addendum) covering sign mounting details (including, but not limited to breakaway assemblies, typical section, post spacing, and extruded aluminum panel details), which is Standard Plan 903.03BH.
3. Sheet G-105 (Sign Type D), G-110 (Sign Type E), and G-111 (Sign Type F)
 - a. Note Clarification
 - i. Original Note:
 1. The selected fabricator will be responsible for engineering posts, panels and mounting methods that adhere to MoDOT specifications.
 - ii. Revised Note:
 1. **For non-decorative posts**, the selected fabricator will be responsible for engineering posts, panels and mounting methods that adhere to MoDOT specifications. **For decorative posts, the manufacturer's specifications shall be adhered to.**
4. Sheet G-105 (Sign Type D – District Vehicular Directional)
 - a. POLE Notes
 - i. The specified items for Decorative Post (Large) are revised as follows:
 1. Post: 4" OD Pipe Post
 - a. System G coating shall be applied as noted on Plan Sheet 2 of 40
 2. Base: 2PCL8-4 or approved equal
 3. Finial: FIN-B4 or approved equal
 - ii. Breakaway and Color notes remain in full force and effect.
5. Sheet G-111 (Sign Type F – Pedestrian Directional)
 - a. POLE Notes
 - i. The specified items for Decorative Pole are revised as follows:
 1. Post: 3" OD Pipe Post with fluted sleeve cover or 3" OD Fluted Pipe Post. Approved equals of alternate sizes and materials will be accepted provided they are engineered to accommodate the specified sign size.
 2. Base: SB-93 or approved equal to match chosen post size.
 3. Finial: FIN-B3 or approved equal to match chosen post size.
 - ii. Breakaway and Color notes remain in full force and effect.

2) JOB SPECIAL PROVISION CHANGES

The following Job Special Provisions are revised as follows

J. SIGN POSTS

2.2.1 Acceptable Manufacturer Systems. The chosen post type **for each sign type** shall be the same for all sign locations requiring decorative posts for this project as shown on the plans.
(Remainder of paragraph 2.2.1 remains in full force and effect)

Contact information for Metalcraft Industries, Inc. is revised as follows:

120 Cypress Road

Ocala, FL 34472

Phone (352) 680-3555

Website: www.metalcraftindustries.net

3) FEDERAL WAGE RATE REVISION:

The Federal Wage Rate in effect for this project is as follows:

General Decision Number MO16001 04/15/2016

BARTLETT & WEST, INC.

Jason Sommerer, P.E., PTOE
Project Engineer

