

January 15, 2016

**ADDENDUM NO. 2**  
**2014PW0057T TAP-5901 (805)**

**PROJECT:** MAIN AVENUE STREETSCAPE – PHASE 1  
**BID OPENING:** 10:30 a.m., January 22<sup>nd</sup> – Bush Building 2<sup>nd</sup> Floor **ROOM 285**, City of  
Springfield, Missouri

---

This addendum forms a part of the Bid Documents for the project described above. The original Bid Documents and any prior addenda remain in full force and effect except as modified by the following, which shall take precedence over any contrary provision in the prior documents. The following clarifications are made:

**Clarifications:**

1. **Bid Item E7:** 1" schedule 40 PVC, perpendicularly slotted pipe with 3 single rows of 0.125" wide slots on 120 degree center along pipe circumference with 1" row spacing. 11 slot rows per foot of running pipe. Pipe shall be wrapped in the fabric specified on sheet 15.

**In order to have a valid bid proposal, this addendum must be acknowledged and returned with your bid proposal.**

If you have any questions concerning this addendum, please feel free to contact Jonathan Peitz at (417) 864-1994.



Jonathan Peitz, EIT  
Public Works Department  
City of Springfield, Missouri

Acknowledgement by Bidder:

\_\_\_\_\_  
Representative

\_\_\_\_\_  
Date

\_\_\_\_\_  
Company