

BIDDING AND CONTRACT DOCUMENTS
ADDENDUM NUMBER TWO
MoDOT PROJECT NO. 14-017A-1

DATE: SEPTEMBER 4, 2015

HIGGINSVILLE INDUSTRIAL MUNICIPAL AIRPORT

CRAWFORD, MURPHY, TILLY, INC.
ONE MEMORIAL DRIVE, SUITE 500
SAINT LOUIS, MISSOURI 63102

TO: ALL PLANHOLDERS AND POTENTIAL BIDDERS

SUBJECT: ADDENDUM NUMBER ONE TO THE BIDDING DOCUMENTS FOR:
CONSTRUCT PRE-ENGINEERED 5-UNIT HANGAR;
FURNISH AIRPORT BEACON



This addendum forms a part of the bidding and contract documents, and modifies the original bidding documents dated August 13, 2015 and Addendum No. 1 dated August 14, 2015. This addendum must be signed on the last page and included with the submitted Bid Package. An acknowledgement sheet is also attached. This must be signed and returned to Crawford, Murphy, & Tilly, Inc via fax or mail by September 9, 2015. FAILURE TO NOT RECOGNIZE THE ADDENDUM ON THE BID FORM MAY SUBJECT THE BIDDER TO DISQUALIFICATION.

The Contract Documents are revised as follows:

CONTRACT PROPOSAL:**Page 1, SECTION 1 – NOTICE TO BIDDERS**

REPLACE in the section titled **Contract Time** the words “seventy five (75)” with “one hundred ten (110)”.

Page 112

ADD to the end of section 152-2.9 the following:

Any topsoil stockpiles to be left in place shall be seeded and mulched using the following seeding mix.

Alta Fescue or Kentucky 31 Fescue	25 lb/acre
Rye Grass	25 lb/acre
Creeping Red Fescue	15 lb/acre

Mulch shall be vegetative mulch consisting of straw and shall have adequate coverage to the satisfaction of the Engineer. Establishment of turf shall consist of a consistent stand of grass with at least 70% coverage as determined by the Engineer. This work shall be considered incidental to the contract.

Page 126

REPLACE in the first sentence of Section 610-3.2 the word “3,000” with “3,500”.

Page 126

REPLACE the second paragraph of Section 610-3.3 with the following:

Concrete cylindrical test specimens shall be made by the Contractor in accordance with ASTM C 31 and tested for acceptance as part of the Contractor Quality Control testing at 28 days in accordance with ASTM C 39. The Contractor shall cure and store the test specimens under such conditions as directed. See Section 1.10 of Item 03000 for additional testing requirements.

Page 137

REPLACE in the sixth sentence of Section 1.02.B. the words “seventy five (75)” with “one hundred ten (110)”.

Page 148

ADD to the end of the list of building manufacturers in Section 1.09.A. the following:

"6. Mesco Building Solutions; (800) 556-3726"

Page 150

REPLACE section 1.09.H.2) with the following:

Each bi-fold door shall be equipped with locks that automatically unlatch as the open button is pressed at the control station. Upon closing of the bi-fold door the locks shall either automatically or manually latch.

Page 151

REPLACE section 1.09.H.3) C. with the following:

Each bi-fold door shall be equipped with exterior automatic Limit Switches to turn off the motor when the door reaches the fully open or closed position. Additional exterior limit switches or controls shall be provided to stop the door upon failure of the automatic door locks or over-travel of the door when opening.

Page 152

ADD to the end of section 1.09.J.1) the following:

Partitions sheets are only required on one side of the structural framing.

Page 168

REPLACE in item g. the words "seventy five (75)" with "one hundred ten (110)".

Page 182

REPLACE in Article 5 the words "seventy five (75)" with "one hundred ten (110)".

PLANS**Sheet 3 of 8**

REPLACE in PHASING NOTES, Note 2. of 2. PHASING the word "75" with "110".

REPLACE in PHASE 2 NOTES, Note 3. of 2. PHASING the word "75" with "110".

CLARIFICATION:

The contract time for the construction phase is being increased to 110 calendar days.

Any topsoil stockpile to remain in place shall be seeded and mulched.

An alarm light in the control station is not required.

CRAWFORD, MURPHY & TILLY, INC.

This Addendum consists of 1 page plus a fax transmittal sheet.

Signed
(Contractor)

Date

Contractor to sign and date this Addendum #2 to acknowledge receipt. This signed Addendum must be included with the submitted Bid Package.

FAX TRANSMITTAL

To: Crawford, Murphy & Tilly, Inc

Attention: **Brian Garkie**

Re: Addendum #2

Fax 314.436.0723

From:

(name)

(company)

Date:

To verify that all contractors are in receipt of this addendum, Contractors are asked to sign and date this acknowledgement sheet. The Contractor should fax, mail or e-mail to Crawford, Murphy, & Tilly, Inc. at the number listed below by **September 9, 2015**.

Crawford, Murphy, & Tilly, Inc.
One Memorial Drive, Suite 500
Saint Louis, Missouri 63102

Fax: (314) 436-0723
Phone: (314) 436-5500
E-Mail: bgarkie@cmtengr.com

BY: CRAWFORD, MURPHY, & TILLY, INC.