

August 26, 2015

To: Plan Holders for Improvements to the  
Kennett Memorial Airport  
Kennett, MO  
State Block Grant No. 15-079C-1

Transmitted herewith is Addendum **No. 3** to the Contract Documents and Specifications dated July 30, 2015, for Improvements to the Kennett Memorial Airport, Kennett, Missouri.

**SCHEDULE I:**

Construct 4-Unit Box Hangar

**SCHEDULE II:**

Construct Taxiway Widening

**SCHEDULE III:**

Install Gate Operator

Sincerely,

Jviation, Inc.



Andy Remstad, AIA  
Project Manager



Main 303.524.3030  
Fax 303.524.3031

900 S. Broadway | Suite 350 | Denver, CO | 80209

ENGINEERING & PLANNING

JVIATION.COM

**ADDENDUM NO. 3  
TO  
CONTRACT DOCUMENTS AND SPECIFICATIONS  
FOR IMPROVEMENTS TO THE  
KENNETT MEMORIAL AIRPORT  
KENNETT, MISSOURI  
State Block Grant No. 15-079C-1**

To All Bidders: You are requested to make all changes and/or additions contained in this addendum to the Bidding Documents. Failure to acknowledge this Addendum in Proposal shall result in rejection of bid. Bidders are informed that the above referenced Contract Documents and Specifications are modified as follows as of August 26, 2015:

**QUESTIONS**

1. A manufacture's roof weather tight warranty is not available in a screw down roof. A roof weather tight warranty is only available with a standing seam roof panel.
  - a. The requirements for the weather tightness warranty per Specification 13 3419 1.7 Warranty, B. Roof Weather tightness Warranty, shall be deleted from the project requirements.

**\*\* END OF ADDENDUM NO. 3 \*\***

**No more questions will be accepted prior to the bid opening.**