

June 26, 2015

To: Plan Holders for Improvements to the  
Kirksville Regional Airport  
Kirksville, Missouri  
Project No. 14-028A-3  
Reconstruct Air Carrier Apron (Schedule I), Reconstruct South Apron (Schedule II),  
and Reconstruct T-Hangar Taxilanes (Schedule III)

Transmitted herewith is Addendum **No. 1** to the Contract Documents, Plans and  
Specifications dated June 16, 2015 for Improvements to the Kirksville Regional  
Airport, Kirksville, Missouri, Project No. 14-028A-3.

**SCHEDULE I:**

Reconstruct Air Carrier Apron

**SCHEDULE II:**

Reconstruct South Apron

**SCHEDULE III:**

Reconstruct T-Hangar Taxilanes



Sincerely,

**Jviation, Inc.**

A handwritten signature in blue ink that reads "Elizabeth Duvall".

Elizabeth Duvall, P.E.  
Project Engineer

**ADDENDUM NO. 1  
TO  
CONTRACT DOCUMENTS, PLANS AND SPECIFICATIONS  
FOR IMPROVEMENTS TO THE  
KIRKSVILLE REGIONAL AIRPORT  
KIRKSVILLE, MISSOURI  
PROJECT NO. 14-028A-3**

To All Bidders: You are requested to make all changes and/or additions contained in this addendum to the Bidding Documents. Failure to acknowledge this Addendum in Proposal shall result in rejection of bid. Bidders are informed that the above referenced Contract Documents, Plans and Specifications are modified as follows as of June 26, 2015:

**1. QUESTIONS / CLARIFICATIONS**

Q. There is conflicting information regarding what is needed to accompany the proposal. Under Section 2 "Instructions to Bidders" the apparent low bidder shall submit evidence of competency and evidence of financial responsibility no later than 3 days after bid opening. But, under Section 20 "Proposal Requirements and Conditions" bidders are to furnish the owner evidence of competency and evidence of financial responsibility at the time of bid opening. Could you please clarify what you want here and if you do need it at bid opening what Forms do you need for evidence of competency?

A. *Section 2 "Instructions to Bidders" is accurate. The apparent low bidder will have 3 days after the bid opening to submit documentation for competency and financial responsibility. Bidders are required to be in good standing with the Missouri Secretary of State and not debarred. Bid Bond can be evidence of financial responsibility.*

Q. Your quantity for lime treated subgrade, stabilization fabric, and base rock is 28,807 SY and your quantity for 6" Concrete is 27,143 SY. There is a difference of 1,664 SY, which is more than a 6" overbuild. Please clarify where and why the difference?

A. *The 6 inch overbuild is a minimum and the quantities were calculated anticipating an over-build slightly larger than the minimum. An overlap between phases was also accounted for in the quantities. The over-build along the phase break lines may need cutback thus additional quantity was added for this situation.*

**\*\* END OF ADDENDUM NO. 1 \*\***