



CITY OF COLUMBIA, MISSOURI

FINANCE DEPARTMENT
PURCHASING DIVISION

NOTICE TO BIDDERS
ADDENDUM #1 RFQ: 76/2015 – CPP-9999(511)
Hominy Creek Trail Phase II

Inbox x

Bidders shall note these changes to the above Request for Quotation and *incorporate these changes in their submittal*. Bidders shall attach a signed acknowledged copy of this addendum to their bid, if submitting a hard copy (via paper) or agree to the addendum electronically if submitting through the electronic bid system on line.

The following revisions and/or additions shall be referred to as part of the Bid/Contract Documents.

General Clarifications:

1. As per section 724 of the “2011 Missouri Standard Specifications for Highway Construction” Group A pipe is being allowed for storm drainage pipe (round Sections only), in lieu of the Reinforced Concrete Pipe (RCP) and Corrugated Metal Pipe (CMP) as described in the plans and specifications. No quantities have been revised. Bidders may quote Group A pipe on the lines specified for RCP and CMP in the bid documents. The type of pipe quoted will not impact the evaluation of the bid.
2. Will the statement “Contractors must do 30% of the work” be enforced?
Yes, this is a MODOT requirement.
3. *No other Changes*

ACKNOWLEDGEMENT OF ADDENDUM #1

The undersigned Respondent hereby certifies that the changes set forth in this Addendum #1 have been incorporated in their proposal and are a part of Request for Quotation No. 76/2015. All other provisions of the bid documents, except as herein stated, shall remain in force as written.

Firm _____ Date _____

Signed _____