

ADDENDUM NUMBER <u>3</u>

Project Number <u>SBMO 11001</u>

Project Title <u>Cliff Drive Recreational Improvements</u>

ISSUE DATE: <u>June 10, 2014</u>

Bidders are hereby notified that the Bidding and Contract Documents for the above project, for which Bids are to be received on **June 11, 2014**, are amended as follows:

Information to Bidders: The following is provided to Bidders for information only:

Q1.	What is the correct thickness of the 6' wide concrete walk at the stair landings?
A1.	4 inches. Per General Condition 3.01 D, scaled details shall govern over no-scale
	details. Detail 4 of sheet S-100 shows a 4" thick concrete walk at the landing.

NOTE	

NOTE: Bidders must acknowledge receipt of this Addendum by listing the number and date, where provided, on the Bid Form - Document 00410.