



CITY OF WASHINGTON, MISSOURI

Department of Planning & Engineering

405 Jefferson Street · Washington, MO 63090

Phone (636) 390-1010 · Fax (636) 239-4649

ADDENDUM #1

City of Washington, Missouri

Fourteenth and Stafford Street Resurfacing Project, STP-6402(601)

May 15, 2014

1. ADA ramps that lead to private drives do not require truncated domes. The 10 ADA ramps shown on plan sheet 7 of 13 at the following private drive locations do not require truncated domes:

STA 79+75 Left
STA 80+20 Left
STA 80+50 Left
STA 81+00 Left
STA 82+35 Left

STA 82+85 Left
STA 83+50 Left
STA 83+85 Left
STA 85+25 Left
STA 85+65 Left

2. The call out on Sheet 7 of 13 near STA 95+00 states “Asphalt Walkway Remove and Replace with ADA Ramp (333 SqFt) Included in Bid Item # 15”. This ADA ramp will be paid in Bid Item # 18 ADA Access Ramps at an approximate quantity of 333 SqFt. It will not be paid in any other Bid Item.

Thank you,

Andrea F. Lueken, P.E.
Assistant City Engineer