



## **ADDENDUM NUMBER ONE**

**DATE:** April 4, 2014  
**OWNER:** City of Clayton, Missouri  
10 N. Bemiston Ave.  
Clayton, Missouri 63105  
**SUBJECT:** Addendum Number One  
**Wydown Boulevard Resurfacing Project**  
**STP 5438 (610)**  
Project No. **2014.PW.1401.010**

---

This Addendum forms a part of the Bidding and Contract Documents and modifies the original Bidding Documents. **FAILURE TO ACKNOWLEDGE RECEIPT OF ADDENDUM MAY SUBJECT BIDDER TO DISQUALIFICATION.** Any modification of the work or additional work that the bidder may be required to perform by reasons of this addendum shall be included. All work under this addendum shall be governed by the main specification for such work.

---

### **ITEM:**

1. **CLARIFICATION:** Specification Section 609.2-Clayton's design standards typically require an 8.5-sack mix for curb and gutter, as we need high early strength, since curbs being replaced are often at corners, and are at high risk for vehicular damage. In order to facilitate the use of slip-form pavers for the long stretches of curb and gutter replacement, we will allow a 6-sack mix design. However, the 6-sack mix will only be allowed for use in curb and gutter in conjunction with slip-form paving. This mix must reach 3,500 psi at seven (7) days and 4,500 psi at twenty-eight (28) days, and must be protected from traffic until it has reached 3,500 psi. Any curb and gutter that is hand-formed or a potential target for drive-over at intersections shall still be poured using a 8.5-sack mix.
2. **REPLACE:**
3. **ADD:**

**END ADDENDUM NUMBER ONE**