

**CITY OF RUSSELLVILLE, MISSOURI
SAFE ROUTES TO SCHOOL SIDEWALK IMPROVEMENTS
FED. PROJECT NO. SRTS-INF-H31D(103)
ADDENDUM NO. 1 – JULY 2, 2013**

Bid Opening: Wednesday, July 3, 2013 at 9:00 A.M. Local Time
Project No. 16995.007

ENGINEER
BARTLETT & WEST, INC.
1719 Southridge Dr., Suite 100
Jefferson City, Missouri 65109
Phone: (573) 634-3181

OWNER
City of Russellville
13203 Railroad Avenue
Russellville, MO 65074
Phone: (573) 782-3511

Notice is hereby given to bidders that in reference to the subject project, the following modifications shall be noted. All other aspects of the Contract Documents remain in full force and effect. This addendum will **NOT** extend the date of the bid opening. **Acknowledgment of this addendum is required on the Bid Form.**

Clarifications:

Bid Items 726-13.15 and 726-13.18 for 15" Class III Reinforced Concrete Pipe and 18" Class III Reinforced Concrete Pipe, respectively, will allow for the substitution of Flexible Pipe – Thermoplastic Group A Pipe (Polypropylene Pipe Double Wall or Polyethylene Pipe Corrugated or Steel Reinforced) per Section 724 of the Specifications. However, the substitution of the Flexible Pipe – Thermoplastic, in lieu of reinforced concrete pipe shall require the use of pipe anchors to be installed at no extra cost. These pipe anchors shall be furnished and installed with the pipe and included in the contract unit price for Bid Items 726-13.15 and 726-13.18. Below is a brief technical specification for pipe anchors.

PIPE ANCHORS

- A. Unless shown otherwise on the plans, all Flexible Pipe will be installed with a pipe anchoring system consisting of galvanized or stainless steel rods with a minimum of 4" diameter auger placed on either side of the pipe, connected over the top of the pipe with a strap. Strapping shall fit snug against the pipe in the groove between pipe corrugations.
- B. Hardware for strapping connections and strap shall be the same material as the rods.
- C. Anchors shall be placed on approximately 3 feet from each pipe end, except at structure connections. Anchors shall be placed at outlet or inlet ends of pipes attached to end sections.

The Addendum is being sent by FAX or email to the Bidders List today: Tuesday, July 2, 2013. The Addendum will not be mailed due to the short timeframe. Contact the Engineer if further clarification is required.

BARTLETT & WEST, INC.



Bob Gilbert, P.E.
Project Manager

