

Addendum

EDM Incorporated
220 Mansion House Center
St. Louis, MO 63102-1902

Tel: 314 231 5485
FAX 314 231 8167
edm@edm-inc.com



EDM of Illinois, Inc
850 Vandalia, Suite 25
Collinsville, Illinois 62234

Tel: 618 344-3774
FAX 618 344-5773
edm@edm-inc.com

Re: Fee Fee Road Improvements, STP-5408(605), TIP 5251-10

Project Number: 10148

Date: May 3, 2013

ADDENDUM #3

THIS ADDENDUM AMENDS THE CONTRACT DOCUMENTS OF THE ABOVE TITLED PROJECT DATED **February 15, 2013** FOR BID **May 7, 2013**, AND SHALL BE INCORPORATED INTO THE CONTRACT DOCUMENTS AS PART THEREOF.

SPECIFICATIONS:

None.

DRAWINGS:

- Sheet XS1: Corrected cut/fill quantities for stations 11+00, 11+13, and 11+36.72.
- Sheet XS2: Corrected cut/fill quantities for stations 11+50, 12+00, 12+20.49, and 12+50.
- Sheet XS3: Corrected cut/fill quantities for stations 13+00, 13+09.23, and 13+50.
- Sheet XS4: Corrected cut/fill quantities for stations 14+00, 14+50, 15+00, and 15+50.
- Sheet XS5: Corrected cut/fill quantities for station 15+62.15.
- Sheet XS11: Corrected cut/fill quantities for station 24+00.

GENERAL CLARIFICATIONS (BIDDER QUESTIONS):

1. Do the excavation quantities shown on the cross sections include the existing pavement?

Response: Yes. When discussing the question with the bidder, EDM discovered that some of the cut/fill quantities listed on the cross section sheets did not match the values used to compute the plan quantities. The plan quantities shown on the "Bid Form" and "2A & 2B Sheets" for bid items "Class A Excavation" and "Compacting Embankment" are correct.

2. Do the excavation quantities shown on the cross sections include the area above the 1 foot extension of the aggregate subbase?

Response: No.

ATTACHMENTS:

Plan Sheets XS1, XS2, XS3, XS4, XS5, and XS11.

END OF ADDENDUM #3







