

BIDDING AND CONTRACT DOCUMENTS
ADDENDUM NUMBER ONE
STATE PROJECT NO. 20-038A-1


DATE: AUGUST 28, 2020

MEXICO MEMORIAL AIRPORT

CRAWFORD, MURPHY, TILLY, INC.
ONE MEMORIAL DRIVE, SUITE 500
ST. LOUIS, MISSOURI 63102

TO: ALL PLANHOLDERS AND POTENTIAL BIDDERS

SUBJECT: ADDENDUM NUMBER ONE TO THE BIDDING DOCUMENTS FOR:
REPLACE RUNWAY 18-36 EDGE LIGHTING



This addendum forms a part of the bidding and contract documents, and modifies the original bidding documents dated August 5, 2020. This addendum must be signed on the last page and included with the submitted Bid Package. An acknowledgement sheet is also attached. This must be signed and returned to Crawford, Murphy, & Tilly, Inc via e-mail by September 1, 2020. FAILURE TO NOT RECOGNIZE THE ADDENDUM ON THE BID FORM MAY SUBJECT THE BIDDER TO DISQUALIFICATION.

The Contract Documents are revised as follows:

CONTRACT PROPOSAL

Page iii

REPLACE in the Description of No. 8, Item L-109-6.2 the words "L-828, 7.5KW Ferroresonant Regulator" with "L-828, 10KW Ferroresonant Regulator".

Page 170

REPLACE in Basis of Payment for Item L-109-6.2 the words "L-828, 7.5KW Ferroresonant Regulator" with "L-828, 10KW Ferroresonant Regulator".

Page 207

REPLACE in Bid Item 8, Spec. No. L-109-6.2 of the proposal form the words "L-828, 7.5KW Ferroresonant Regulator" with "L-828, 10KW Ferroresonant Regulator".

PLANS

Sheet 1 of 19

REPLACE in the Description of Item # L-109-6.2 of the Summary of Quantities the words "L-828, 7.5KW FERRORESONANT REGULATOR" with "L-828, 10KW FERRORESONANT REGULATOR".

CLARIFICATIONS

As noted on the Electrical Vault Details plan sheets, the existing regulator is a 10KW and the new regulator shall match the size of the existing. No new proposal form will be issued. Bidders shall cross out 7.5 and write in 10.

CRAWFORD, MURPHY & TILLY, INC.

This Addendum consists of 2 pages and an acknowledgment transmittal sheet.

Signed
(Contractor)

Date

Contractor to sign and date this Addendum #1 to acknowledge receipt. This signed Addendum must be included with the submitted Bid Package.

TRASMITTAL

To: Crawford, Murphy & Tilly, Inc

Attention: **Brian Garkie**

Re: Addendum #1

E-mail: bgarkie@cmtengr.com

From:

(name)

(company)

Date:

To verify that all contractors are in receipt of this addendum, Contractors are asked to sign and date this acknowledgement sheet. The Contractor should e-mail to Brian Garkie of Crawford, Murphy, & Tilly, Inc. at the e-mail address listed below by **September 1, 2020**.

Phone: (314) 436-5500

E-mail : bgarkie@cmtengr.com

BY: CRAWFORD, MURPHY, & TILLY, INC.