

**PROJECT 190913  
VILLA DRIVE SIDEWALK AND SIGNAL MODIFICATIONS  
TAP-990 (319)**

BID DATE: Thursday, October 22, 2020, 10:00 a.m. CST

**ADDENDUM NO. 1**

October 16, 2020

TO ALL PLANHOLDERS:

The following changes, additions, and/or deletions are hereby made a part of the Contract Documents for the above referenced project, as fully and completely as if the same were fully set forth therein. All bidders submitting a Bid on the above Contract shall carefully read this Addendum and give it consideration in the preparation of their bid. **Acknowledgement of Addendum No. 1 must be made on the Bid Form by an authorized representative of the Bidder, or the bid will be considered unresponsive.**

**This Addendum No. 1 consists of the following:**

The concrete base specification for the Lighting Pole, 12 FT, Black, Ornamental shall be modified to include a Type C Base in accordance with Section 902 of the Missouri Department of Transportation Standard Plans, and Missouri Department of Transportation Standard Specifications for Highway Construction, most current version. JSP L, Paragraph 2.0 shall be deleted and replaced with the following:

Job Special Provisions

**L. POLE FOUNDATION, 12 FT**

2.0 The ornamental light post shall be constructed on a concrete base, Type C Base, per Section 902.15.1. Concrete bases for posts shall be in accordance with the dimensions shown on MoDOT Standard Drawing 902.30P. The top 12" of the Type C bases shall be round, not square. Reinforcing steel for concrete bases shall be in accordance with Sec 706. Anchor bolts for steel posts and mast arms shall be as shown on the fabricator's approved shop drawings. Conduit shall extend above all post bases a nominal 4 inches.

Screw-in footings may be used in lieu of concrete bases at no additional cost to the City.

**END OF ADDENDUM NO. 1**