



ADDENDUM NUMBER 3

Project Number **CMAQ 3319(412), City Project 70171305**

Project Title **I-35 and Chouteau Parkway
Interchange Improvements**

ISSUE DATE: **11/16/2020**

Bidders are hereby notified that the Bidding and Contract Documents for the above project, for which Bids are to be received on **November 18, 2020**, are amended as follows:

Information to Bidders The following is provided to Bidders for information only:

1. Agenda of the pre-bid conference meeting held on November 4, 2002 are provided.
2. Updated utility information related to existing and proposed Evergy systems are shown on sheet

Q1.	Pages 58-60 on the plans call out for temporary traffic signals, there is no discernable pay item listed on the project that capture these. Please clarify if this will be paid as a subsidiary item construction, or if there is an intended pay item(s) for this.
A1.	Additional bid items have been added to the project. Section 00412 Unit Prices is to be replaced with the attached revised document.
Q2.	Is the temporary signal at Chouteau and Cleveland required? Phasing sheet 49 states that phase 1 should include the new signal installation and the existing signal to remain operational. However, sheets 53-57 reference sheet 58 in the plans which detail a temporary signal. If required, is there supposed to be a bid item for the temporary signal?
A2.	Temporary signal at Chouteau and Cleveland is required. Refer to A1 response above.
Q3.	Is demolition and removal of the existing full depth pavement included in the Unclassified Excavation Quantity of 4,489 CY.
A3.	Excavation quantity was considered to the bottom of the aggregate rock base/top of subgrade of the proposed roadway. If the existing pavement extends below this elevation it is not included in the excavation quantity.
Q4.	Was there anything in the addendum 1 to address the traffic control.
A4.	Addendum information and documents are available on the KCMO Plan Room website.

Bidding Requirements

1. N/A

Contracting Requirements

1. N/A

Specifications

1. Replace 00412 Unit Prices in its entirety.

Drawings: Replace the following drawings

1. N/A.

NOTE: Bidders must acknowledge receipt of this Addendum by listing the number and date, where provided, on the Bid Form - Document 00410.