

Waters Engineering, Inc.

Civil Engineering and Land Surveying

Post Office Box 567
908 S. Kingshighway
Sikeston, Missouri 63801

E-mail: main@waterseng.com
(573) 471-5680
Fax: (573) 471-5689

**ADDENDUM NO. 1
TO THE CONTRACT DOCUMENTS FOR
HANGAR CONSTRUCTION
DEXTER MUNICIPAL AIRPORT
PROJECT 20-081A**

Original Bid Date: February 23, 2021

TO ALL PLANHOLDERS VIA E-MAIL:

The Contract Documents for the hangar improvements for the City of Dexter are changed as follows:

1. BID DATE.

The bid date is changed to March 9, 2021, the time and place remain the same.

2. HANGAR BUILDING PLANS AND SPECIFICATIONS.

2.1 Floor Finish.

The floor finish shall be the hardener/sealer as noted in Job Special Provision 4, Paragraph 11. A non-skid epoxy finish will not be required.

2.2 Fasteners for Wall & Roof Systems.

The wall and roof systems shall be installed with manufacturer's standard corrosion resistant screw fasteners with washers. Concealed fasteners will not be mandatory.

2.3 Roof Vent.

A 10-foot long roof vent shall be provided for each unit.

2.4 End & Back Wall Angles.

The end and back wall angles do not require fuel resistant sealant.

2.5 Single Source Supply.

Single source supply provisions shall not apply to the hangar building and the bi-fold doors.

2.6 Codes.

The City of Dexter uses the 2006 IBC Code and the 2008 NEC Code.

Please acknowledge your receipt of this Addendum by an E-mailed response to our E-mailed transmittal, and also be sure to acknowledge receipt of this Addendum in the space provided on the bid form.



John Chittenden, PE

February 16, 2021
Date



*** End of Addendum No. 1 ***