

ADDENDUM NO. 1

PROJECT TE1818 - NE 76th Street Improvements – N. Oak to N. Brooklyn

GLADSTONE, MISSOURI

DATE: 3/22/21

This Addendum forms a part of the Contract described above. The original Contract Documents and any prior addenda remain in force and effect except as modified by the following which shall take precedence over any provisions in the prior documents

Addendum No. 1:

Corrections/Changes:

1. Stormwater Pipe Material – There is a discrepancy between the pipe materials listed on the Bid Form and the Project Drawings. The size and pipe materials that will be used on the project shall be as listed on the Bid Form.
2. All stormwater concrete structure lids shall be permanently marked with “No Dumping-Drains to Stream” or similar message.
3. Asphalt Index – The asphalt index for bidding purposes to shall be \$425 per ton for February 2021.
4. Electrical Junction Boxes – All electric junction boxes (Bid Items 56 and 57) shall be constructed of fiberglass reinforced polymer concrete and listed on MoDOT Traffic Operations Approved Products List.

Each Bidder shall acknowledge receipt of this addendum by fixing their signature below, by noting this addendum on their Proposal, and by attaching this addendum to their Bid.

ACKNOWLEDGEMENT

The undersigned acknowledges receipt of this addendum and the Bid submitted is in accordance with information, instructions and stipulations set forth herein.

Bidder _____

By: _____

Date: _____