

LETTER OF TRANSMITTAL

DATE: June 8th, 2021

TO: All Prospective Bidders

FROM: Emily Wicoff, P.E.

RE: Stanberry SRTS TAP-9900(128)
Stanberry, Missouri
Addendum No. 1

CONTENT: The following is Addendum No. 1 for the above reference project. **Please complete the confirmation portion from this addendum and fax it back to our office at (816) 364-6086 or scan and email to akatakis@snyder-associates.com** to ensure that you have received the addendum.

**CONFIRMATION OF RECEIPT
ADDENDUM NO. 1**

This is to confirm that we did receive Addendum No. 1 for the above
referenced project on this _____ day of _____, 2021.

Company: _____

By: _____

Addendum No. 1**Stanberry SRTS TAP-9900(128)
Stanberry, Missouri**

All Prospective Bidders:

The following clarifications are provided in response to Contractor questions. Contract documents remain unchanged.

A. CONTRACTOR QUESTIONS AND ANSWERS

- 1) **Q:** Shall sidewalk panel joints be tooled or sawcut?
A: The City prefers sawcut with broom finish. In the case of concrete driveway repair, jointing and finish shall match existing.
- 2) **Q:** Can concrete debris be disposed of at a City facility?
A: The City will accept concrete debris at a disposal site adjacent to the City Barn. Contractor is responsible for transportation to and offloading at the disposal site.
- 3) **Q:** Who removes the existing landscaping bricks located within the improvement area at the Funeral Home (5th and Alanthus)?
A: Contractor is responsible for all demolition activities including and related to brickwork removal, gravel/landscape area, and existing driveway. Bricks shall be given to the Funeral Home if requested, otherwise bricks may be disposed near the City Barn.
- 4) **Q:** Regarding traffic control, are flaggers required full-time or may they be used only during concrete pour or truck offloading?
A: Refer to 'Job Special Provisions', paragraph E, in the specifications. The Contractor is responsible for traffic control and jobsite safety.

B. PLAN CLARIFICATIONS

1. See attached 'Funeral Home Drive Profile' for clarification on plan grading shown on Plan Sheets 3.05 and 3.06. Plan sheets 3.05 and 3.06 remain unchanged.

The above interpretations and alterations are hereby made a part of the contract documents and supersede all other addenda or interpretations.

Issued this Eighth (8th) day of June 2021.

SNYDER & ASSOCIATES


Emily Wicoff, P.E.

