

**July 24, 2023**

**ADDENDUM #1**

**IFB 23-043**

**GGL Phase 6 Fiber Expansion and ITS Device Installations**

**Questions**

1. Is the conduit on structures to be rigid steel or aluminum?
  - a. Aluminum
2. Are two conduits being installed on the TR Hughes Blvd bridge as shown on the plans, sheet F19?
  - a. No, this note is incorrect. Only one (1) conduit shall be installed on this bridge.

---

**Bidders shall sign this Addendum as acknowledgement and return it with the bid**

**IFB 23-043**

**GGL Phase 6 Fiber Expansion and ITS Device Installations**

**Addendum #1**

**Dated 07/24/2023**

**We, the undersigned, acknowledge the receipt of the above addendum, as dated.**

**By:** \_\_\_\_\_

**Title:** \_\_\_\_\_

**Company:** \_\_\_\_\_

**Date:** \_\_\_\_\_