

**ADDENDUM NO. 2**  
**October 22, 2024**  
**CITY OF LAKE SAINT LOUIS, MISSOURI**

**Lake Saint Louis Boulevard Sidewalk and Enhancement Project**  
**TAP-5418(622)**

**BID NO. 07-21**

This addendum is to announce and self as official notice that there are changes to the City of Lake Saint Louis’s Bid Proposal Bid No. 17-21.

**Bid Item Changes/Clarifications**

**Item 201-20.20 Removal of Improvements – Shall include all asphalt milling costs. No additional payment will be made for milling of existing asphalt. The quantity of milling to include in Removal of Improvements is 4,570 SY.**

**Item 405-30.10 2” Type “C” Bituminous Concrete (Pavement ) or Superpave - All references to surface course, Type “C” Bituminous Concrete (Pavement) or Superpave shall mean Modot BP-1 PG 64-22. Mix shall not include recycled shingles (RAS)**

**Item 405-30.30 6” Type “X” Bituminous Concrete (Base) - All references to 6” Type “X” Bituminous Concrete (Base) shall mean Modot Bit Base. Mix shall not include recycled shingles (RAS)**

To ensure the integrity of the bid process, a signed copy of this addendum notice shall be included with your company’s bid submittal.

\_\_\_\_\_  
(Print Name)

\_\_\_\_\_  
(Date)

\_\_\_\_\_  
(Signature)

\_\_\_\_\_  
(Company Name)