

City of Lawson, MO  
103 S. Pennsylvania Ave.  
PO Box 185  
Lawson, MO 64062



Phone: 816-580-3217  
FAX: 816-580-3914  
sdobbins@lawsonmo.gov

---

**Salem Road – Lawson, MO  
Hazel Ave. to Route D  
Job No. STBG 3301(536)**

**June 4, 2025  
ADDENDUM No. 1**

The Contract Documents and Design Plans are hereby modified and clarified as follows:

---

**Item #1 – Period of Performance**

- The period of performance in Section (3) of the Notice to Contractors shall be revised to read as the following:

(3) **PERIOD OF PERFORMANCE:** If the bid is accepted, the bidder agrees that work shall be diligently prosecuted at such rate and in such manner as, in the judgment of the engineer, is necessary for the completion of the work within the time specified as follows in accordance with Sec 108:

Calendar Days: 389 calendar days  
Completion Date: August 28, 2026

- Job Special Provision B shall be revised to read as the the following:

**B. Contract Liquidated Damages JSP- 13-01D**

**1.0 Description.** Liquidated Damages for failure or delay in completing the work on time for this contract shall be in accordance with Sec 108.8.

**2.0 Period of Performance.** Prosecution of work is expected to begin on the date specified in the Notice to Proceed. Contract times shall be 389 calendar days.

**3.0 Liquidated Damages.** In accordance with General Condition 108.8 if the entire project is not ready for final payment within 389 calendar days from notice to proceed and any time extensions granted then the contractor will be charged with liquidated damages specified in the amount of \$1225.00 per calendar day that the work is not complete.

City of Lawson, MO  
103 S. Pennsylvania Ave.  
PO Box 185  
Lawson, MO 64062



Phone: 816-580-3217  
FAX: 816-580-3914  
sdobbins@lawsonmo.gov

---

## **Item #2 – Pipe Material for pipes not under the roadway**

- The following pipe segments will be allowed to be bid as High-Density Polyethylene Pipe (HDPE) as specified in section 2600 of the Specifications and Standards of The Kansas City Metropolitan Chapter of the American Public Works Association.
  - A2 to A1 (with HDPE End Section)
  - C5 to C4 (with HDPE End Section)
  - C4 to C3
  - C2 to C1 (with HDPE End Section)
  - D2 to D3
  - D3 to E1 (with HDPE End Section)
  - D4 to D3
  - F2 to D4

All measurement and payment specifications will remain the same with the exception of HDPE shall replace RCP where applicable.

The following bid items and quantities were added to the plans and bid form to reflect the changes:

- 22A, FLARED END SECTION (42") (RCP OR HDPE)
- 26A, STORM SEWER, RCP OR HDPE (42")
- 27A, STORM SEWER, RCP OR HDPE (36")
- 30A, STORM SEWER, RCP OR HDPE (15")

In addition, the following bid item and quantities were modified in the plans and bid form:

- 22, FLARED END SECTION (42") (RCP)
- 23, FLARED END SECTION (36") (RCP OR HDPE)
- 24, FLARED END SECTION (15") (RCP OR HDPE)
- 26, STORM SEWER, RCP (42")
- 27, STORM SEWER, RCP (36")
- 28, STORM SEWER, RCP OR HDPE (24")
- 30, STORM SEWER, RCP (15")

Plan sheets 4, 10, 12, 17 and 18 and the bid form were modified and included in this addendum.

City of Lawson, MO  
103 S. Pennsylvania Ave.  
PO Box 185  
Lawson, MO 64062



Phone: 816-580-3217  
FAX: 816-580-3914  
sdobbins@lawsonmo.gov

---

**Item #3 – Cable Retainer / Anti-Theft Devices NOT REQUIRED**

- Cable Retainer / Anti-Theft Devices (see Note #10 on Plan Sheet 48) will not be required and the note will be struck from the plans. Plan sheet 48 is included in this addendum