

**ADDENDUM NO. 1  
TO  
MACON-FOWER MEMORIAL AIRPORT (K89)  
OBSTRUCTION REMOVAL  
(MODOT AVIATION PROJECT NO: 26-031A-2)**

**Addendum Date: April 27, 2026**

**To Prospective Bidders:**

The contract documents/specifications and plans for the above referenced project are hereby amended as follows:

**Contract Documents/Specifications:**

*None*

**Plans:**

*None*

**Questions and Clarifications:**

**Entry 1:** Bidders are advised that environmental testing has confirmed the presence of lead-based paint within the east structure (1315 Vine Street) to be removed with the project. The Contractor shall be responsible for performing demolition and disposal activities in accordance with all Federal, State, and Local environmental regulations. Results of the lead-based paint test are included as an attachment to this Addendum No. 1.

**END OF CHANGES PER ADDENDUM NO. 1**



**Prepared/Approved By:  
Elizabeth S. Duvall, PE, Project Manager**

Alfred Benesch & Company  
4451 West 107<sup>th</sup> Street, Suite 250  
Overland Park, KS 66207

**HOWE COMPANY, LLC**  
804 E. Patton St.  
Macon, MO 63552

WO# C-1007856  
Report Date: 04/21/2026  
Test Date: 04/17/2026  
Page 1 of 1

**Attention: Tom Heald**

**REPORT OF ANALYSIS**

**MATERIAL:** 1A- Paint on Wood Chip from Secondary Exterior wall  
1B- Paint Chips from Exterior wall

**SUBJECT:** Lead Content

**TEST METHOD:** STL-EIP-001 (ASTM E2594-20-Modified)

**STANDARD:** 16 CFR 1303: Lead in Paint


**UNITS:** Parts Per Million (ppm)

**RESULTS:**

Sample	Lead	Method Detection Limit
1A- Paint on Wood Chip from Secondary Exterior wall	4050	40
1B- Paint Chips from Exterior wall	< 40	40

The lead content of the 1A- Paint on Wood Chip from Secondary Exterior wall is not in compliance with the requirements of the above indicated standard.  
The lead content of the 1B- Paint Chips from Exterior wall is in compliance with the requirements of the above indicated standard.

BA/mlb

  
Brenden Allen (Apr 22, 2026 11:17:30 CDT)  
Brenden Allen, Manager  
Chemical Testing



IIA Lab Services – St. Louis, warrants that the testing services provided herein have been performed, findings obtained and reports prepared in accordance with generally accepted testing laboratory principles and practices, subject to generally accepted margins of error for the instruments used in performing the tests. All testing is performed at the St. Louis location, unless otherwise noted within the body of the report. No other warranties are either expressed or implied. No opinions, conclusions or warranties are rendered by IIA Lab Services – St. Louis as to fitness of the sample for any particular purpose other than compliance with the specific code standards to the extent that such code standards are specifically set forth on the front of this report.

These tests were conducted in accordance with the standards and procedures specified. The analysis and/or tests have been made and report prepared, based upon results from specific samples identified and supplied by the client or their representatives. IIA Lab Services – St. Louis assumes no responsibility for, nor makes any warranties for any extrapolation of data from the test results and relating such test results to any batch, lot or material from which IIA Lab Services – St. Louis had no control of sample acquisition.

This report is furnished in strict confidence for the exclusive use of the client or their representative, and no distribution of all or part of the report shall be made to third parties without the prior written approval of the company or individual ordering the work. Official reports will be provided only by IIA Lab Services – St. Louis and will contain a watermark to certify authenticity. Revision or modification of these reports by anyone other than IIA Lab Services – St. Louis is prohibited. A hard copy will be provided on request, for a fee.

If during or after the performance of these tests it is necessary for IIA Lab Services – St. Louis to recreate reports, assemble materials, gather additional information, or perform other work with regard to these test results to assist in the preparation for any investigation, civil proceeding, or criminal action, regardless of who makes such a request or issues a subpoena, client shall reimburse Laboratory for out of pocket expenses incurred in relation to such work. Client further agrees to compensate Laboratory at a rate of \$400.00 per hour for any such work which is required, including any time devoted to testifying in depositions, at hearings, or in court.

Only tests requested by the client are those that are set forth on the front of this report. There may be additional tests which could be performed on the sample but which client has not requested IIA Lab Services – St. Louis perform. Client releases and holds IIA Lab Services – St. Louis harmless for any damages which may have been discovered, avoided, or mitigated as a result of any additional testing not requested by client.

IIA Lab Services – St. Louis will dispose of samples 30 days after issuance of a formal report, unless specifically requested in writing by the client or their representative to return the samples to them. Samples may be stored at IIA Lab Services – St. Louis for an extended period of time, provided a written agreement incorporating monetary considerations is executed.