

ADDENDUM NO. 1



Engineering beyond.™

TO: All Holders of Plans and Contract Documents for City of Holden TAP 3400(452) Constructing or Improving Holden Sidewalk Improvements

ISSUED: September 17, 2026

Name of Bidder

Receipt Acknowledged By

This Addendum is hereby made a part of the Contract Documents to the same extent as if it were originally included herein. This Addendum shall be inserted in the Contract Documents and submitted with the Bid, and includes the following items:

CONTRACT DOCUMENTS:

- Applicable Federal Wage Rates
 - Page 71-100
 - Replaced "Federal Prevailing Wage MO20260001 07/30/2026, MOD 3" with "Federal Prevailing Wage MO20260001 08/27/2026 MOD 4"

GENERAL QUESTIONS:

- On Demo sheet 11-12 there are diagonal lines through the sidewalk area. What is meant by that?
 - Diagonal lines through the sidewalk indicate existing sidewalk that is to be removed, reference Note 1
- When the plans call to demo a gravel or concrete driveway is that only in the area of the sidewalk?
 - Demo of gravel or concrete driveways will be to the extents called out in the demo plans with stations and offsets.
- Does the city have a location to take spoils?
 - The city has some potential locations within city limits to take spoils and can be discussed and scheduled upon award of contractor
- Does the city have a place for stockpiling rock and dirt and a place to park equipment overnight?
 - The city has some potential locations within city limits to stockpile material and park equipment overnight and can be discussed and scheduled upon award of contractor
- Can you provide any additional information about the water hydrant adjustments? Are they vertical adjustments or horizontal adjustments?
 - Water hydrant adjustments are only vertical adjustments

Sincerely,

A handwritten signature in blue ink that reads "Mitch Gibler".

Mitch Gibler
Project Manager