



**ADDENDUM NUMBER 2  
REQUEST FOR BID  
FOR PROJECT NO. 70191308  
BLUE RIVER TRAIL CONNECTOR –  
MARTHA TRUMAN ROAD  
PARKS AND RECREATION DEPARTMENT  
CITY OF KANSAS CITY, MISSOURI**

ISSUE DATE: **10/25/2024**

Proposers are hereby notified that the above project, for which Bids are to be received on **November 6, 2024**, is amended as follows:

**Pre-Bid Meeting Agenda and Question and Answer information is attached.**

**Revise Section 01800 Contractor Provided Surveying and Construction Staking as follows:**

**Add:**

**G.1. Submit “As-Constructed” plan for the portion of trail installed from Station 24+00 to 31+00 prepared and sealed by a Missouri registered land surveyor. This includes surveyed elevations of trail at 50 ft intervals at center line, both pavement edges, and both toes of slope for flood permit updates.**

**NOTE: Proposers must acknowledge receipt of this Addendum 2. This signed addendum notice must accompany your proposal.**

---

**CERTIFICATE BY BIDDER/PROPOSER**

I acknowledge receipt of this Addendum No. 2 for Project No. 70191308 Project: Blue River Trail Connector - Martha Truman Road and that the bid is in accordance with the information, instructions, and stipulations set forth herein.

By \_\_\_\_\_

Company \_\_\_\_\_



## PRE-BID CONFERENCE AGENDA

**Project Number – TAP 3301 (519) 70191308**

**Project Title – Blue River Trail Martha Truman Road Connector**

**Location: Microsoft Teams Virtual Meeting**

[Click here to join the meeting](#)

Meeting ID: 235 260 688 301

Passcode: eqnstS

[Download Teams](#) | [Join on the web](#)

**Or call in (audio only)**

[+1 872-212-5076,,71468588#](#) United States, Chicago

Phone Conference ID: 714 685 88#

**Date: October 23, 2024**

**Time: 2:00 PM**

### **INTRODUCTIONS**

**A. Project Representatives:**

Project Manager: Lisa Treese - (816) 513-7619

E-Mail: [lisa.treese@kcmo.org](mailto:lisa.treese@kcmo.org)

MoDOT Project Manager: Katie Jardieu - (816) 607-2136

E-Mail: [katie.jardieu@modot.mo.gov](mailto:katie.jardieu@modot.mo.gov)

Planning Division Senior Admin. Assistant: Janies Shannon - (816) 513-7617

E-Mail: [janies.shannon@kcmo.org](mailto:janies.shannon@kcmo.org)

CREO Representative: Valerie Johnson - (816) 513-1406

E-Mail: [Valerie.johnson@kcmo.org](mailto:Valerie.johnson@kcmo.org)

**B. DESIGN PROFESSIONAL Representatives:**

Project Manager: Valerie McCaw - (816) 914-1788

E-Mail: [vmccaw@vsmkc.com](mailto:vmccaw@vsmkc.com)

Consultant(s): VSM Engineering

**C. Others:**

Mark McIntyre – [mmcintyre@vsmkc.com](mailto:mmcintyre@vsmkc.com) - (816) 589-5395

Sarah Schultz - [sschultz@vsmkc.com](mailto:sschultz@vsmkc.com) - (816) 308-3532

### **General Requirements:**

Bid Date/Time : November 6, 2024, at 2:00 p.m.

Bid Submittal Location: 4600 E. 63<sup>rd</sup> St., Kansas City, MO 64130 – Parks & Rec. Dept.

DBE approved goals: 8% DBE

**Bid Documentation (packet):**

- Bid Structure (Unit Prices Bid)

- Requirements are stated in the advertisement. Pay attention to the documents due.

Period of Performance:

- Completion Date: November 14, 2025

Liquidated Damages:

- Liquidated Damages per EPG 136.9.4.1.1.2 23 CFR 635.127 MoDOT Spec 108.8 shall be as follows: \$950 per day

Licenses and Permits

CONTRACTOR, at its own expense, shall secure or cause to be secured all licenses and permits from public or private sources necessary for the fulfillment of its obligations under this Contract.

Invoicing and Submittals

eBuilder/Trimble Unity Construct document management system

Substitution Requests

Proposed "or-equal" items must be submitted to CITY at least 7 days prior to Bid date.

**Technical Requirements:**

- Project Overview
  - Project consists of construction of 10-foot wide concrete trail with associated signage installation and pavement markings.
  - Contractor to coordinate field tests with KCMO Public Works Testing Lab (Testing Agency).
  - Tree removals are only to occur between November 1 and March 31. Limit clearing to those shown on plans which indicates only those tree removals that are necessary to complete the project.
  - Designated wetlands not to be impacted
  - Coordinate with existing trails to remain (dirt trails – mountain biking/equestrian)
  - Utilities
    - Google Fiber Line
  - Shop Drawing submittal requirement for erosion and sediment control (see Sheet 2, Note 45)
  - Traffic Control Plan submittal requirement (Sheet 2, Note 81)
- Drawings:
  - Project drawings review
  - CADD file available
- Project Specifications:
  - Contractors are encouraged to thoroughly read and review the project specifications.

**QUESTION AND ANSWER PERIOD**

Q1. Which testing lab will be used?

A1. It will be the KCMO Public Works Testing Lab.

Q2. Would a different type of pipe be allowed for the pipe under the trail?

A2. If you are requesting a substitute material, please submit it as a substitution request.

Q3. Is the driveway on the plans required to be reinforced as a driveway or can welded wire mesh be used?

A3. This is indicated on the driveway detail on Sheet 18.

Q4. Compaction testing is required at a high frequency on page 317 of the project manual PDF. Is this the requirement for the trail subgrade?

A4. The testing required on page 317 of the project manual PDF (Section 2102.12) applies to trench backfill in cases where flowable fill is not used. Trail subgrade preparation requirements are included in Section 2201.3 (project manual PDF pages 433 and 434).