

ADDENDUM NO. 1

ISSUED BY: Howe Company LLC
804 E. Patton Street
Macon, MO 63552


12-1-2023

DATE: December 1, 2023

FOR: PUTNAM COUNTY BRIDGE 11800171
BRO-R086(29)

The attached revisions hereby supersede any and all data with which they may conflict as indicated on the Drawings, Specifications and related documents issued in the original set. Each trade is responsible for changes in its work caused by changes in the work of other trades. This addendum is a part of and shall be attached to the original set of plans and specifications for the work.

THIS ADDENDUM SHALL BECOME A PART OF THE SPECIFICATIONS NOTED ABOVE. RECEIPT OF THIS ADDENDUM SHOULD BE ACKNOWLEDGED ON THE BID FORM.

In lieu of galvanizing the fabricated structural steel girders and diaphragms, these items may be painted with two coats of inorganic zinc-rich primer that is a two component, ethyl silicate-based, zinc-rich coating that provides cathodic resistance to properly prepared substrates. The dried film shall contain at least 85% zinc. The surfaces to be painted shall be abrasive blast clean in accordance with SSPC-SP-6 Commercial Grade with a 1-3 mil surface profile.

The galvanizing requirement for the bolts remains in place.

There is no change in bid opening date or time.