

ADDENDUM 02

Issued: 11/01/2024

Project: Vivion Rd Trail Segment 1
PROJECT NO: TAP 3454(401)

Engineer: McClure
Matt Eblen
913-307-2588
meblen@mcclurevision.com

This addendum forms a part of the contract documents and modifies the original procurement documents dated October 2024.

ITEM

- 1. The number calendar days to complete the project has been extended from 150 days to 180 days.**
- 2. The contractor shall provide for additional traffic control in the base bid as necessary to perform the shoring while keeping EB/WB traffic open along Vivion Road.**
- 3. It is assumed that any removal of vegetation at and around the culvert will be included in the "Clearing, Grubbing & Demolition" line item.**
- 4. The project number listed on Addendum 01 was incorrect. The correct project number is listed on Addendum 02.**

EMAILED QUESTIONS AND ANSWERS

- 1. For subcontractors are Exhibit W and Exhibit S both part of the paperwork that is submitted 3 days after bids are due? Yes, Exhibit W and page 2 of Exhibit S (for subcontractors) are both due 3 days after the bid opening. Exhibit S, page 1, for the prime contractor is due with the bid submittal.**
- 2. Is the temporary shoring quantity supposed to be a square foot quantity instead of a linear foot quantity?**
The quantity is meant to be a linear foot quantity, as it was assumed 1' wide sheet piles would be driven to the length mentioned in Addendum 1 (2,187 ft).
- 3. Line item 18 (Formliner) - is the quantity supposed to be 916 square feet instead of 1,442 square feet?**
1,442 is the correct quantity.

THIS IS THE END OF ADDENDUM 02 – 0 Attachments