



January 2, 2025

213-025

ADDENDUM NO. 1 for January 2025 Re-bid

TO: Prospective Bidders and Others Concerned

RE: City of Kahoka Downtown Sidewalk Project TAP-9900(392)

The original Plans, Specifications, and Contract Documents remain in full force and effect except as revised by the following changes, which take precedence over any wording to the contrary in the Contract Documents.

This Addendum shall be attached to Bidder's Bid and Contract Documents and acknowledged on the Bid as having been received.

CONTRACT DOCUMENTS AND SPECIFICATIONS

Item #1:

Aluminum handrailing shall not be powder coated. All railing shall be fabricated from 6061-T6 or 6063-T6 aluminum alloy. Slip joints are permitted in the rail in manner that prevents any transverse/lateral movement between adjacent sections of railing.

Item #2:

Sidewalk joints may be tooled or alternately be sawcut 1/4-inch wide x 1/2-inch minimum depth.

END OF ADDENDUM NO. 1

James D. Bensman, PE, SE.

MO PE #2001018705

ADDENDUM NO. 1 RECEIVED AND ACCEPTED BY:

Signature

Date