

CITY OF SAINT LOUIS

DEPARTMENT OF THE PRESIDENT, BOARD OF PUBLIC SERVICE

ADDENDUM NO. 2

TO

PLANS AND SPECIFICATIONS

FOR

**RECONSTRUCTION OF HAMILTON BRIDGE
OVER METROLINK**

ST. LOUIS, MISSOURI

DATE: 5/28/24
LETTING NUMBER: 8772

The following changes and additions shall be made in the plans and to the estimate. The cost thereof shall be included in the proposals submitted by the bidders.

Receipt of this addendum must be acknowledged in Bid Express.

ADDENDUM TO THE SPECIFICATIONS

- **Revise "JSP T - BRIDGE LIGHTING, Section 2.0 Materials" as follows:**
 - **Delete** the following statement: "Nominal dimensions: 8.5"w x 48"l x 4" high."
 - **Delete** the following statement: "Driver shall be constant current at 350 mA, input voltage rated from 100 to 277 VAC."
 - **Add** the following statement: "The luminaire shall be compatible with an input voltage of 480V."

ADDENDUM TO DRAWINGS

- **Revise the general notes on Sheet LT-02 (Sheet 16 of 72) as follows:**
 - **Delete** the following general note: "Nominal dimensions: 8.5"w x 48"l x 4" high."
 - **Delete** the following general note: "Driver: Constant current at 350 mA, input voltage rated from 100 to 277 VAC."
 - **Add** the following general note: "The luminaire shall be compatible with an input voltage of 480V."

SUBMITTED QUESTIONS AND ANSWERS

Question:

Can fiber be added to the concrete mix design?

Answer:

"JSP V – Concrete Mix Design" requires that fiber is added into the concrete mix of the bridge deck slab and bridge approach slabs. Reference Sections 2.3 and 2.5 for fiber dosage requirements.

END OF ADDENDUM NO. 1