



Finance Department

Invitation for Bids

**CITY OF LEBANON
ADDENDUM NUMBER 1
SPRINGFIELD ROAD OVERLAY
BID NUMBER: ST-08-181218-F-314**

December 3, 2018

Bidders should acknowledge receipt of Addendum 1 (one) by signing and including it with the original bid. The due date for receipt of proposals remains unchanged by this Addendum. Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential Bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer

Signature

Date_____

The mix placed should conform to specifications 401 or 403 with the minimum requirement for the overlay as specification 401, BP-1 mix. Improved 403 mixes are acceptable but are not mandatory. The contractor should be mindful that there are different testing and payment provisions within the specifications depending upon the mix selected and should state which mix they are proposing in the bid.