

FEDERAL PROJECT NOS. CMAQ-5417(603)  
& STP-5417(604)  
BPS PROJECT NO. 2019-40-098

CITY OF SAINT LOUIS

DEPARTMENT OF THE PRESIDENT, BOARD OF PUBLIC SERVICE

\*\*\*\*\*

**CLARIFICATION NO. 1**

TO

SPECIFICATIONS

FOR

**JEFFERSON AVE / 22<sup>ND</sup> ST. CORRIDOR IMPROVEMENTS**

ST. LOUIS, MISSOURI

DATE: **1/13/22**  
LETTING NUMBER: **8739**

Addendum #1, issued 1/11/22, included a revision to "JSP#56 - Parking Lot Lighting System" to change the height of the specified pole from 30' to 25'. Within the original JSP were two references to the pole height being 30', however the revised JSP inadvertently only changed the first reference. This clarification is being issued to confirm that the correct pole height for the parking lot lights is 25'.

Note: Contractors do not need to acknowledge receipt of this design clarification on the bid form, but contractors **must** acknowledge receipt of Addendum #1.

END OF CLARIFICATION NO. 1