

February 8, 2022

To: Plan Holders for Improvements to the
Hannibal Regional Airport
Hannibal, Missouri
MoDOT Project No. 21-049A-1

Transmitted herewith is Addendum **No. 4** to the Issued for Bid Contract Documents, Specifications and Plans dated January 11, 2022 for Improvements to the Hannibal Regional Airport.

Schedule I – Runway 17/35 Lighting Rehabilitation

As a reminder, bids are due Thursday, February 10, 2022 at 2:00 PM.

Sincerely,

Jviation, A Woolpert Company

Isaac De la Cruz, PMP.
Project Manager

**ADDENDUM NO. 4
TO
CONTRACT DOCUMENTS, SPECIFICATIONS AND PLANS
FOR IMPROVEMENTS TO THE
HANNIBAL REGIONAL AIRPORT
HANNIBAL, MISSOURI
MODOT PROJECT NO. 21-049A-1**

To All Bidders: You are requested to make all changes and/or additions contained in this addendum to the Bidding Documents. Failure to acknowledge this Addendum in Proposal shall result in rejection of bid. Bidders are informed that the above referenced Contract Documents, Specifications and Plans are modified as follows as of January 20, 2022:

1. PLANS

E252 (27 of 29) – ELECTRICAL DETAILS:

In Detail 1, REIL INSTALLATION SECTION DETAIL, in the note that reads “NEW L-849I, STYLE E LED REIL. AIM LIGHT OUTWARD 15° FROM R/W CENTERLINE AND 10° ABOVE HORIZONTAL. PROVIDE BAFFLES FOR ALL UNITS” delete the text that reads “PROVIDE BAFFLES FOR ALL UNITS”. The note shall now read “**NEW L-849I, STYLE E LED REIL. AIM LIGHT OUTWARD 15° FROM R/W CENTERLINE AND 10° ABOVE HORIZONTAL.**” The callout will be updated with the issued for construction set of plans.

Justification: The REILs will not be baffled

2. QUESTIONS

In regards to the REIL baffle, please advise amount of beam being baffled (I.E. – Desired Beam)

Answer: The REILs will not need to be baffled. See item 1 above.

Page 4-41 of the specifications, Grade Control and Surface Tolerance. It appears this section applies to paving projects, please confirm that this requirement as detailed in this section is not required on the project.

Answer: Paving is not included in the scope of the project. All survey needed for the installation of lighting will be responsibility of the contractor.

I was at the pre-bid for the Hannibal Lighting Upgrade. I have spoke with a contractor that is interested in bidding this as a general. I would bid to him. He has more resources then what an electrical contractor would have. He has worked on projects in Missouri and Iowa. Since he was not at the pre-bid. I was not sure if he would be able to bid as a prime contractor.

Answer: The Pre-Bid Conference was non mandatory, however all bidders are required to examine the site to become familiar with all site conditions. Per the Pre-Bid Conference all bidders are invited to

come by the site during regular hours any time prior to bidding. They will need to check in at the terminal to get a radio if they want to access the AOA.

**** END OF ADDENDUM NO. 4 ****