

ADDENDUM NO. 1

ISSUED BY: Howe Company LLC J.L.
804 E. Patton Street
Macon, MO 63552

DATE: July 16, 2026

FOR: Bethany Pool to School Sidewalk Project
TAP 9900(152)

The attached revisions hereby supersede any and all data with which they may conflict as indicated on the Drawings, Specifications and related documents issued in the original set. Each trade is responsible for changes in its work caused by changes in the work of other trades. This addendum is a part of and shall be attached to the original set of plans and specifications for the work.

THIS ADDENDUM SHALL BECOME A PART OF THE SPECIFICATIONS NOTED ABOVE. RECEIPT OF THIS ADDENDUM SHOULD BE ACKNOWLEDGED ON THE BID FORM.

This addendum clarifies that the ADA Handrail shall be galvanized after fabrication in accordance with AASHTO M111 and painted black.