



CITY OF ST PETERS
636.477.6600
bids@stpetersmo.net

November 15, 2017

Addendum 2 - Bid 18-107; Jungermann Road Bridge Replacements, Federal Project No. BRM 5640 (613)

To all Contract Bidders of Record,

This Addendum, consisting of two (2) pages, is issued to answer questions received, modify, explain, or correct the original contract documents as noted below, and is hereby made a part of the contract documents.

The bid opening has been extended until 2:00 PM, Tuesday, November 28, 2017.

1. Will a precast concrete alternate be acceptable for the proposed 13' x 7' Double Cell Pre-Cast Box Culvert?
 - A precast alternative will be considered, however, maintaining two lanes of traffic (one in each direction) throughout construction is a requirement of the project. The width and skew of the proposed culvert required a staged construction joint parallel to the centerline of roadway in order to have sufficient room to maintain two lanes during each stage.
 - Any changes must meet the requirements of the Highway Bridge Program. The current plans have a designed edge beam that runs parallel to the CL of Roadway and was designed to support loads for the staged construction. Precast box sections will not have a designed edge beam, so the staged traffic will need to maintain proper distance from the ends of the precast sections so that traffic loads are properly transferred to the box sections.
 - Changing from a cast in place culvert to a precast culvert would change the load ratings for the structure. The EOR would need to submit the manufacturer's or do their own calculations for the load rating of the structure. The ratings must be submitted to the District and/or the Bridge Division at MoDOT. As built plans of the box culvert and reinforcement details of the precast sections must also be provided for documentation into MoDOT's bridge management system.
- A. Important: Label the lower left corner of your sealed submittal package with the bid number and name
- B. Submit one original and one copy of your bid proposal
- C. Include with Proposal Sections:
 - **C – Proposal**
 - **D – Bid Bond**
 - **O – Addendum**
 - **S – Affidavit of Enrollment in Federal Work Authorization (with E-Verify)**
 - **V – Disadvantaged Business Enterprise Contact Provisions**
 - **W – Buy America Certification**

Thank you,
City of St. Peters
bids@stpetersmo.net

Section – O - Addenda

ADDENDUM ACKNOWLEDGEMENT: The undersigned states that the all addenda's have been received, acknowledged and incorporated into their proposal, prior to submittal. Complete and return with this proposal.

Addendum #1 – November 3, 2017
Addendum #2 – November 15, 2017

Addendum
Received By: _____

Signed: _____
(Signature of Authorized Representative)

Name _____
(Printed Name of Authorized Representative)

Title _____

Date _____