

RECEIPT OF ADDENDUM

I received addendum No. # 03 for November 27, 2024
Albany Avenue Pedestrian and Stormwater Improvements
Federal: TAP-6701(807)
ARPA: AB82D393425B
GRE: 4689

This addendum involves 2 pages including this sheet.

Vendor's Name

Vendor's Address

Signature / Date

**Return completed acknowledgment to
Great River Engineering ASAP**


Email Back to:

Secretary@greatriv.com

OR

Fax # 417-886-7591

Attention: Ramona Giddens



GRE
GREAT RIVER
ENGINEERING

ADDENDUM NO. 3

ISSUED BY: Great River Engineering
2826 S. Ingram Mill Road
Springfield, Missouri 65804
(417) 886-7171
(417) 886-7591 -- FAX

DATE: November 27, 2024

FOR PROJECT: **Albany Avenue Pedestrian and Stormwater Improvements**
Federal: TAP-6701(807)
ARPA: AB82D393425B
GRE: 4689

This Addendum is applicable to work herein and shall be understood to be and is an Addendum, and as such shall be a part and included in the Contract. IT IS ESSENTIAL THAT ALL BIDDERS, CONTRACTORS, SUBCONTRACTORS, AND ALL MATERIAL SUPPLIERS READ ALL SECTIONS OF THIS ADDENDUM.

Contractor Inquiries:

In response to an inquiry from a plan holder, a 10' (wide) x 5' (height) box culvert would be acceptable in lieu of the double-cell 5' (wide) x 5' (height) box culvert as shown on the plans, provided that there is no cost increase for such use. The bid form will not be updated to reflect this.

END OF ADDENDUM NO. 3

