



ADDENDUM NUMBER TWO

DATE: November 5, 2024

OWNER: City of Valley Park, Missouri

SUBJECT: Addendum Number Two to
St. Louis Avenue Phase 3 Improvements
Federal Project No. STP-9901(651)
Cochran Project No. SC20-1130

This Addendum forms a part of the Bidding and Contract Documents and modifies the original Bidding Documents. **FAILURE TO ACKNOWLEDGE RECEIPT OF ADDENDUM MAY SUBJECT BIDDER TO DISQUALIFICATION.**

ITEM:

1. CLARIFICATION: All concrete driveway approaches shall be **6" thick**. The approaches shown on plan sheets S-2, S-3, and S-4 are labeled incorrectly.
2. CLARIFICATION: Thickness for the gutter section of the curb and gutter shall be 6".

END ADDENDUM NO. 2