



Greg Horn, Interim District Engineer

**ADDENDUM 001  
REQUEST FOR BID  
SL14-030-RW, Bridge Epoxy Overlay, McDonnell**

Bidders shall acknowledge receipt of Addendum 001 (ONE) by signing and including it with original bid. The due date for receipt of this bid **does not change** by this Addendum. Accordingly, the following clarifications, additions/deletions, questions and answers are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority  Teresa (Terri) Mount Sr. Procurement Agent St. Louis District
Bidder Signature	Department of Transportation  <i>Terri Mount</i>
<input type="text" value="Signature of person authorized to sign"/>	<input type="text" value="Authorizing Signature"/>
Date Signed:	Date Signed: September 12, 2013

Regarding Friday's 10am bid, "SL14-030-RW Bridge Epoxy Overlay McDonnell, St. Louis County" I have a question to ask the engineer regarding the pavement markings.

Question: Can the replacement striping be Acrylic Waterborne Pavement Marking Paint or must it be Preformed Marking Tape (Grooved)? Note: the existing left arrows and 24" white stop bars are Type II Preformed Marking Tape (Grooved).

**MoDOT Response:**

An approved Acrylic Waterborne Pavement Marking Paint that is applied according to MoDOT Standards is acceptable. We do not wish to apply any delineation/striping that requires grinding for "insetting" that will damage the epoxy overlay.

**THIS PAGE MUST BE SIGNED AND RETURNED WITH ORIGINAL RFB.**