

Missouri Department of Transportation
Roberta Broeker, Interim Director

573.751.2551
Fax: 573.751.6555
1.888.ASK MODOT (275.6636)

ADDENDUM 001 Request for Bid King City Maintenance Building RFB 9-150708KH

Bidders should acknowledge receipt of Addendum 001 (ONE) by signing and including it with the original bid. The due date for receipt of bids **has not** changed by this Addendum; the due date is **July 8, 2015 2:00 PM Central Time**. Accordingly, the following clarifications, and or additional information, are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

| | |
|--|---|
| Name and Title of Signer (Print or type) | Name and Title of Department Authority Kristi Hixson General Services Senior Specialist |
| Contractor/Offeror Signature (Signature of person authorized to sign) | Department of Transportation <i>Kristi Hixson</i> (Authorizing Signature) |
| Date Signed: | Date Signed: 6/9/2015 |

Plan Sheet:

- Sheet 2, finished floor elevation is 1104.83'.
- Sheet 27, Electric Schedule **ADD** Lighting Fixture AA – Equal to William's, 75L-4-LED*PH50/835-A12125-ED*PH-UNV, LED, 51 watts, ceiling mounted, 2-3/4" x 48", 22 gauge die-formed, C.R.S. shielding: acrylic pattern #12, 1.25" thick.
- Sheet 27, **REMOVE** Electrical Note 13: Provide conductors and conduit to transformer 100'-0"± to pole east of new building as required for a functional service.

