

Missouri Department of Transportation
Roberta Broeker, Interim Director

573.751.2551
Fax: 573.751.6555
1.888.ASK MODOT (275.6636)

ADDENDUM 001 Request for Bid Sikeston Working Bays and Cold Storage Building Project RFB 9-150618KH

Bidders should acknowledge receipt of Addendum 001 (ONE) by signing and including it with the original bid. The due date for receipt of bids **has not** changed by this Addendum; the due date is **June 18, 2015 2:00 PM Central Time**. Accordingly, the following clarifications, and or additional information, are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Kristi Hixson General Services Senior Specialist
Contractor/Offeror Signature (Signature of person authorized to sign)	Department of Transportation <i>Kristi Hixson</i> (Authorizing Signature)
Date Signed:	Date Signed: 6/11/2015

Contractor to provide a 3' x 3' x 3' unreinforced concrete pier below all the wood columns that are 4'-0" below grade on the Cold Storage side. Widen all the concrete stem wall spread footings on the 101 Working Bay's to 3'-0". Lengthen all the transverse rebar (#4 @ 24" O.C.) and maintain the 3" minimum coverage in stem wall spread footing. The rebar parallel at the bottom of all spread footings now to read: Rebar (4) #4 continuous equally spaced.

