

**Missouri Department of Transportation** 

Roberta Broeker, Interim Director

105 West Capitol AvenueP.O. Box 270Jefferson City, Missouri 65102

573.751.2551 Fax: 573.751.6555

1.888.ASK MODOT (275.6636)

# ADDENDUM 001 Request for Bid Nashua Sanitary Sewer System Project RFB 9-151113KH

Bidders should acknowledge receipt of Addendum 001 (ONE) by signing and including it with the original bid. The due date for receipt of bids **has not** changed by this Addendum; the due date is **November 13, 2015 2:00 PM Central Time**. Accordingly, the following clarifications, and or additional information, are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

| Name and Title of Signer (Print or type) | Name and Title of Department Authority              |
|--|---|
|  | Kristi Hixson<br>General Services Senior Specialist |
|  | Conteral Convictor Content Operation                |
| Contractor/Offeror Signature             | Department of Transportation                        |
|  | Kristi Hixson                                       |
| (Signature of person authorized to sign) | (Authorizing Signature)                             |
| Date Signed:                             | Date Signed:11/4/2015                               |

## **Plan Sheet:**

Sheet C-3 Replace with Revised Sheet C-3 (separate attachment).

Sheet C-4 Replace with Revised Sheet C-4 (separate attachment).

### **Specifications:**

Section 11300 Low Pressure Grinder Pump Station: Clarification; The three grinder pump stations, pump and motors, control panels, junction boxes and all associated appurtenances shall be explosion proof to meet the Missouri Department of Natural Resources (MDNR) requirements and be in compliance with NFPA 820.



# **Bid Document RFB 9-151113KH:**

Page 3, Newspaper Advertisement, Notice to Contractor: Replace with the following:

### **Notice to Contractors**

MoDOT will receive bids at its General Services, Procurement Section, 830 MoDOT Drive, Jefferson City, MO until **2:00 p.m.**, November 13, 2015 for the installation of a sanitary sewer system at MoDOT's Maintenance Complex at 1910 NW Cookingham, Kansas City, MO. Contact Kristi Hixson at 573-526-1975 or <a href="mailto:Kristi.Hixson@modot.mo.gov">Kristi.Hixson@modot.mo.gov</a> to obtain information or download at no charge from: <a href="http://contribute.modot.mo.gov/business/contractor\_resources/FacilitiesConstructionandMaintenance.htm">http://contribute.modot.mo.gov/business/contractor\_resources/FacilitiesConstructionandMaintenance.htm</a>

A pre-bid conference is scheduled for October 28, 2015 at 10:30 a. m. Central Time at MoDOT's Nashua Maintenance Complex at 1910 NW Cookingham, Kansas City, MO.

# **Additional Information**

The contractor will be responsible for any permit fees.